


<b>Prüfbericht-Nr.:</b> <i>Test report no.:</i>	<b>CN24H0M4 001</b>	<b>Auftrags-Nr.:</b> <i>Order no.:</i>	<b>244589441</b>	Seite 1 von 1 Page 1 of 1
<b>Kunden-Referenz-Nr.:</b> <i>Client reference no.:</i>	<b>2262903</b>	<b>Auftragsdatum:</b> <i>Order date:</i>	<b>10.11.2023</b>	
<b>Auftraggeber:</b> <i>Client:</i>	<b>Zhejiang Changcheng Trading Co., Ltd.</b> <i>DianHou Village, Liushi Town, Yueqing City,, Zhejiang P.R. China</i>			
<b>Prüfgegenstand:</b> <i>Test item:</i>	<b>Miniature Circuit-breaker</b>			
<b>Bezeichnung / Typ-Nr.:</b> <i>Identification / Type no.:</i>	<b>YCB9-63</b>			
<b>Auftrags-Inhalt:</b> <i>Order content:</i>	<b>Type Test</b>			
<b>Prüfgrundlage:</b> <i>Test specification:</i>	<b>EN 60898-1:2019</b>			
<b>Wareneingangsdatum:</b> <i>Date of sample receipt:</i>	<b>10.11.2023</b>			
<b>Prüfmuster-Nr.:</b> <i>Test sample no.:</i>	<b>24458944101</b>			
<b>Prüfzeitraum:</b> <i>Testing period:</i>	<b>10.11.2023-10.12.2023</b>			
<b>Ort der Prüfung:</b> <i>Place of testing:</i>	<b>TÜV Rheinland (Shanghai) Co., Ltd.</b>			
<b>Prüflaboratorium:</b> <i>Testing laboratory:</i>	<b>TÜV Rheinland (Shanghai) Co., Ltd.</b>			
<b>Prüfergebnis*:</b> <i>Test result*:</i>	<b>Pass</b>			
<b>geprüft von:</b> <i>reviewed by:</i>	<b>genehmigt von:</b> <i>authorized by:</i>			
<b>Datum:</b> <i>Date:</i> 25-01-2024	<b>Ausstelldatum:</b> <i>Issue date:</i> 25-01-2024			
<b>Stellung / Position:</b> Project Engineer	<b>Stellung / Position:</b> Authorizer			
<b>Sonstiges / Other:</b> This report is created for type approval based on CB certificate and CB reports. Attachment 1: CB certificates – HU- 004782 (1 page) Attachment 2: CB test report – CN24JZ8W 001 (172 page)				
<b>Zustand des Prüfgegenstandes bei Anlieferung:</b> <i>Condition of the test item at delivery:</i>		<b>Prüfmuster vollständig und unbeschädigt</b> <i>Test item complete and undamaged</i>		
<p>* Legende: 1 = sehr gut 2 = gut 3 = befriedigend 4 = ausreichend 5 = mangelhaft P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet</p> <p>* Legend: 1 = very good 2 = good 3 = satisfactory 4 = sufficient 5 = poor P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested</p>				
<p><b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b> <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i></p>				

V05



Ref. Certif. No.

HU-004782

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB

Name and address of the applicant

Zhejiang Changcheng Trading Co., Ltd.  
DianHou Village, Liushi Town, Yueqing City,, Zhejiang  
P.R. China

Name and address of the manufacturer

CNC Electric Group Zhejiang Technology Co., Ltd.  
DianHou Village, Liushi Town Yueqing City, 325603 Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

CNC Electric Group Zhejiang Technology Co., Ltd.  
DianHou Village, Liushi Town Yueqing City, 325603 Zhejiang  
P.R. China

Ratings and principal characteristics

Ue: 230/400VAC or 240/415VAC (1P);  
230/240V or 400/415VAC (2P); 400 or 415V (3P/4P);  
In: 6/10/16/20/25/32/40/50/63A;  
B/C/D-type; Icn=Ics=6,0kA; Icn1=Icn; Uimp: 4,0kV

Trademark / Brand (if any)

CNC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

YCB9-63

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1  
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24JZ8W 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2024-01-29

Signature: Wencai Zhang

10/061SMD 2022-07 rke-fix



Test Report issued under the responsibility of:



<b>TEST REPORT</b> <b>IEC 60898-1</b> <b>Circuit-breakers for over current protection for household and similar installations</b> <b>Part 1 - Circuit-breakers for a.c. operation</b>	
Report Number.....	CN24JZ8W 001
Date of issue.....	12.01.2024
Total number of pages .....	172
Name of Testing Laboratory preparing the Report .....	Zhejiang Testing & Inspection Institute for Mechanical and Electrical Products Quality Co., Ltd (ZTME)
Applicant's name .....	Zhejiang Changcheng Trading Co., Ltd.
Address.....	DianHou Village, Liushi Town, Yueqing City,, Zhejiang P.R. China
<b>Test specification:</b>	
Standard .....	IEC 60898-1:2015, AMD1:2019
Test procedure .....	CB Scheme
Non-standard test method .....	N/A
Test Report Form No. ....	IEC60898_1E
Test Report Form(s) Originator ....	DEKRA Certification B.V.
Master TRF .....	Dated 2021-10-17
<b>Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
<b>General disclaimer:</b>	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description .....	Circuit Breaker for overcurrent protection
Trade Mark .....	CNC
Manufacturer.....	CNC Electric Group Zhejiang Technology Co., Ltd.
Model/Type reference .....	YCB9-63
Ratings .....	Ue: 230/400VAC or 240/415VAC(1P); 230/240VAC or 400/415VAC(2P); 400 or 415VAC(3P/4P) In: 6/10/16/20/25/32/40/50/63A; B/C/D-type; Icn=Ics=6,0kA; Icn1=Icn; Uimp: 4,0kV

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Zhejiang Testing & Inspection Institute for Mechanical and Electrical Products Quality Co., Ltd. (ZTME)
Testing location/ address .....		No 125 Miaohouwang Road Binjiang District Hangzhou, Zhejiang CHINA
Tested by (name, function, signature).....		Gao yunyan Test engineer <i>Gao yun yan</i>
Approved by (name, function, signature).....		Ma Lin Reviewer <i>Malin</i>
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address .....		
Tested by (name, function, signature).....		
Approved by (name, function, signature).....		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address .....		
Tested by (name + signature).....		
Witnessed by (name, function, signature).....		
Approved by (name, function, signature).....		
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address .....		
Tested by (name, function, signature).....		
Witnessed by (name, function, signature).....		
Approved by (name, function, signature).....		
Supervised by (name, function, signature) .....		

**List of Attachments (including a total number of pages in each attachment):****Attachment 1: Photo documentation – 6 pages****Summary of testing:**

The model YCB9-60 according to table C.3 of Annex A, following ratings products were subject relevant test accordingly.

## Sample allocation and test items according to IEC 60898-1 and EN 60898-1

Test sample Rating				Test sequence								
Pole	Curve	In [A]	Class	A	B	C1	C2	D0+D1	D0	E1	E2	E3
1P	D	63	-	1+3	3	3	3	3	-	6	-	-
1P	D	50	-	-	-	-	-	-	1	-	-	-
1P	D	40	-	-	-	-	-	-	1	-	-	-
1P	D	32	-	-	-	-	-	-	1	-	-	-
1P	D	25	-	-	-	-	-	-	1	-	-	-
1P	D	20	-	-	-	-	-	-	1	-	-	-
1P	D	16	-	-	-	-	-	-	1	-	-	-
1P	D	10	-	-	-	-	-	-	1	-	-	-
1P	D	6	-	-	-	-	-	-	1	6	-	-
1P	C	63	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	50	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	40	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	32	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	25	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	20	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	16	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	10	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	C	6	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	63	-	-	3 <sup>a</sup>	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	50	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	40	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	32	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	20	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	16	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	10	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
1P	B	6	-	-	-	-	-	-	1 <sup>b</sup>	-	-	-
2P	D	63	-	-	-	-	2	-	-	3	-	-
2P	D	6	-	-	-	-	-	-	-	3	-	-
4P	D	63	-	1+3	3	3	1	3	-	3	-	-
4P	D	6	-	-	-	-	-	-	-	3	-	-
4P	B	63	-	-	3 <sup>a</sup>	-	-	-	-	-	-	-

D-type circuit breaker type-tested first

C-type circuit breaker D0

B-type circuit breaker D0 + B

a-only do test 9.8

b-only do test 9.10.3

<b>Tests performed (name of test and test clause):</b>	<b>Testing location:</b>
<b><u>Test Sequence A</u></b>	<b>Zhejiang Testing &amp; Inspection Institute for Mechanical and Electrical Products Quality Co., Ltd.(ZTME)</b>
D63; 1POLE (1+3 SAMPLE) page 9	
D63; 4POLE (1+3 SAMPLE) page 20	
<b><u>Test Sequence B</u></b>	
D63; 1POLE (3 SAMPLE) page 31	
D63; 4POLE (3 SAMPLE) page 37	
B63; 1POLE (3 SAMPLE) page 44	
B63; 4POLE (3 SAMPLE) page 44	
<b><u>Test Sequence C1+C2</u></b>	
D63; 1POLE (6 SAMPLE) page 46	
D63; 2POLE (2 SAMPLE) page 49	
D63; 4POLE (4 SAMPLE) page 50	
<b><u>Test Sequence D0+D1</u></b>	
D63; 1POLE (3 SAMPLE) page 54	
D63; 4POLE (3 SAMPLE) page 59	
<b><u>Test Sequence D0</u></b>	
D50; 1POLE (1 SAMPLE) page 64	
D40; 1POLE (1 SAMPLE) page 67	
D32; 1POLE (1 SAMPLE) page 70	
D25; 1POLE (1 SAMPLE) page 72	
D20; 1POLE (1 SAMPLE) page 75	
D16; 1POLE (1 SAMPLE) page 78	
D10; 1POLE (1 SAMPLE) page 81	
D6; 1POLE (1 SAMPLE) page 84	
C63; 1POLE (1 SAMPLE) page 87	
C50; 1POLE (1 SAMPLE) page 89	
C40; 1POLE (1 SAMPLE) page 92	
C32; 1POLE (1 SAMPLE) page 95	
C25; 1POLE (1 SAMPLE) page 98	
C20; 1POLE (1 SAMPLE) page 101	
C16; 1POLE (1 SAMPLE) page 103	
C10; 1POLE (1 SAMPLE) page 106	
C6; 1POLE (1 SAMPLE) page 109	
B63; 1POLE (1 SAMPLE) page 112	
B50; 1POLE (1 SAMPLE) page 115	
B40; 1POLE (1 SAMPLE) page 118	
B32; 1POLE (1 SAMPLE) page 121	
B25; 1POLE (1 SAMPLE) page 124	
B20; 1POLE (1 SAMPLE) page 127	
B16; 1POLE (1 SAMPLE) page 130	
B10; 1POLE (1 SAMPLE) page 133	
B6; 1POLE (1 SAMPLE) page 136	
<b><u>Test Sequence E1</u></b>	
D63; 1POLE (6 SAMPLES) page 138	
D6; 1POLE (6 SAMPLES) page 141	
D63; 2P (3 SAMPLES) page 144	

D6; 2P(3 SAMPLES) page 146 D63; 4P (3 SAMPLES) page 147 D6; 4P(3 SAMPLES) page 149	
<b>Summary of compliance with National Differences (List of countries addressed):</b> <b>EU Group Differences</b>  <input checked="" type="checkbox"/> <b>The product fulfils the requirements of _EN60898-1:2019_____ .</b>	
<b>EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES</b> page 169	<b>Zhejiang Testing &amp; Inspection Institute for Mechanical and Electrical Products Quality Co., Ltd.(ZTME)</b>

**Statement concerning the uncertainty of the measurement systems used for the tests**

(may be required by the product standard or client)

 **Internal procedure used for type testing through which traceability of the measuring uncertainty has been established:**
**Procedure number, issue date and title:**


Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.

 **Statement not required by the standard used for type testing**


(Note: When IEC or ISO standard requires a statement concerning the uncertainty of the measurement systems used for tests, this should be reported above. The informative text in parenthesis should be delete in both cases after selecting the applicable option)

Copy of marking plate


With sample of B40, 1P



With sample of D63, 2P



With sample of D63, 4P






<b>Test item particulars.....: MCB</b>	
<b>Classification of installation and use.....: Circuit Breaker for overcurrent protection</b>	
<b>Supply Connection .....: not associated with the mechanical mounting</b> .....:	
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object.....: N/A	
- test object does meet the requirement.....: P (Pass)	
- test object does not meet the requirement.....: F (Fail)	
<b>Testing.....:</b>	
<b>Date of receipt of test item .....: 01.12.2023</b>	
<b>Date (s) of performance of tests .....: 01.12.2023 to 01.01.2024</b>	
<b>General remarks:</b>	
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.	
<b>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</b>	
<b>Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60898-1:</b>	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided .....	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
<b>When differences exist; they shall be identified in the General product information section.</b>	
<b>Name and address of factory (ies) .....: CNC Electric Group Zhejiang Technology Co., Ltd.</b> DianHou Village, Liushi Town Yueqing City, 325603 Zhejiang P.R. China	
<b>General product information and other remarks:</b> The family products YCB9-63 are series product, according to Annex C in IEC / EN 60898-1. Ratings: Rated voltage 1P: Ue = 230/400VAC or 240/415VAC Rated voltage 2P: Ue = 230/240VAC or 400/415VAC Rated voltage 3P/4P: Ue = 400VAC or 415VAC Rated current In: In= 6/10/16/20/25/32/40/50/63A Instantaneous characteristic: B-type, C-type, D-type Short-circuit Capacity: Icn=Ics=6kA	

<b>Test item particulars</b> .....	
Type of circuit-breaker .....	Circuit Breaker for overcurrent protection
Number of poles .....	<input checked="" type="checkbox"/> 1-P <input type="checkbox"/> 1-P+N <input checked="" type="checkbox"/> 2-P <input checked="" type="checkbox"/> 3-P <input type="checkbox"/> 3-P+N <input checked="" type="checkbox"/> 4-P
Protection against external influences .....	<input type="checkbox"/> enclosed <input checked="" type="checkbox"/> unenclosed
Method of mounting .....	<input type="checkbox"/> surface <input type="checkbox"/> flush <input checked="" type="checkbox"/> panel board
Method of connection .....	<input checked="" type="checkbox"/> not associated with the mechanical mounting <input type="checkbox"/> associated with the mechanical mounting
Type of terminal .....	<input checked="" type="checkbox"/> screw <sup>a) b)</sup> <input checked="" type="checkbox"/> pillar <sup>a) b)</sup> <input type="checkbox"/> cage <sup>a) b)</sup> <input type="checkbox"/> plug <input type="checkbox"/> screw less <sup>a)</sup> <input type="checkbox"/> flat quick connect <sup>a)</sup> <input type="checkbox"/> plug-in <input type="checkbox"/> screw-in <sup>a)</sup> copper conductors <sup>b)</sup> <del>aluminium conductors</del>
Instantaneous tripping current .....	<input checked="" type="checkbox"/> B <input checked="" type="checkbox"/> C <input checked="" type="checkbox"/> D
I <sup>2</sup> t characteristic .....	
Value of rated operational voltage (Ue) .....	<input type="checkbox"/> 120 V <input checked="" type="checkbox"/> 230 V <input checked="" type="checkbox"/> 240 V <input type="checkbox"/> 120/240 V <input checked="" type="checkbox"/> 230/400 V <input checked="" type="checkbox"/> 400 V <input checked="" type="checkbox"/> 240/415 V <input checked="" type="checkbox"/> 415 V
Value of rated current (In) .....	1-63A
Value of rated frequency .....	<input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60 Hz
Ambient air temperature (°C) .....	<input checked="" type="checkbox"/> 30°C <input type="checkbox"/> 40°C <input type="checkbox"/> Other _____ °C
Rated short-circuit capacity (Icn) .....	<input type="checkbox"/> 1,5 kA <input type="checkbox"/> 3 kA <input type="checkbox"/> 4,5 kA <input checked="" type="checkbox"/> 6 kA <input type="checkbox"/> 10 kA <input type="checkbox"/> 15 kA <input type="checkbox"/> 20 kA <input type="checkbox"/> 25 kA
Rated impulse withstand voltage (Uimp)	<input type="checkbox"/> 2,5 kV <input checked="" type="checkbox"/> 4 kV <input type="checkbox"/> declared ___kV

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „A1“ 1 SAMPLE FOR D63, 1P</b>		--
<b>6</b>	<b>MARKING AND OTHER INFORMATION</b>		
	Circuit-breaker marked with:		--
	a) Manufacturer's name or trade mark.....:	Trademark: CNC	P
	b) Type designation, catalogue number or other serial number.....:	YCB9-63	P
	c) Rated voltage (V).....:	230/400 V~	P
	d) Rated current without symbol "A", preceded by the symbol of instantaneous tripping.....:	D63	P
	e) Rated frequency (Hz).....:	50/60Hz	P
	f) Rated short circuit capacity (A).....:	6000A	P
	g) Wiring diagram	See copy of marking plate	P
	h) Ambient air temperature, if different from 30°C		N/A
	i) Degree of protection, if different from IP20		N/A
	j) For D-type circuit-breakers: the maximum instantaneous tripping current, if higher than 20 In see table 2)		N/A
	k) Rated impulse withstand voltage Uimp if it is 2,5 kV	4,0 kV	P
	l) Making and breaking capacity on an individual protected pole of multipole circuit-breakers (Icn1), if different from Icn		N/A
	Marking d) shall be readily visible when the CB is installed		P
	If, for small devices, the available space is insufficient, markings a), b), c), e), f), h), j) and l) may be put on the side or on the back of the CB		N/A
	Marking g) may be on the inside of any cover which has to be removed in order to connect the supply wires but shall not be on a label loosely attached to the CB		N/A
	Any other information not marked shall be given in the manufacturer's documentation		P

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	The suitability for isolation, which is provided by all circuit-breakers of this standard, may be indicated by the symbol on the device		P
	I <sup>2</sup> t characteristic (documentation)		N/A
	Symbols on supply and load terminal		N/A
	Terminal for neutral conductor N		N/A
	Earthing terminal if any (IEC 60417-5019)		N/A
	On - off position shall be clearly indicated - 0 I -		P
	For push-button CB the off push-button shall either be red or be marked with the symbol '0'		N/A
	Red not used for other push-button		N/A
	For CB with multiple current ratings, the maximum value is marked, the adjusted value indicated without ambiguity		N/A
	For rail-mounted circuit-breakers, appropriate rail(s) shall be indicated in the manufacturer's documentation		N/A
	Marking shall be indelible and easily legible (not on removable parts), 15 s with water, 15 s with hexane (see cl. 9.3)		P
<b>8.</b>	<b>REQUIREMENTS FOR CONSTRUCTION AND OPERATION</b>		
<b>8.1.1</b>	<b>General</b>		P
	Circuit-breakers shall be so designed and constructed that, in normal use, their performance is reliable and without danger to the user or surroundings		P
<b>8.1.2</b>	<b>Mechanism</b>		P
	The moving contact shall be mechanically coupled so that all poles make and break together, whether operated manually or automatically, even if an overload occurs on one pole only		P
	The switched neutral shall close before and open after the protected pole (s)		N/A
	Neutral pole having adequate making and breaking capacity and CB with independent manual operation: all poles operate together including neutral pole		N/A
	CB shall have a trip free mechanism		P

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	It shall be possible to switch the CB on and off by hand		P
	No intermediate position of the contacts		P
	Position of contacts shall be indicated		P
	Indication visible from the outside		P
	If the indication is on the actuating means, it shall, when released, automatically take up or stay in the position corresponding to that of the moving contacts; operating means shall have two different rest positions, except that, for automatic operation, a third distinct rest position may be provided		N/A
	If a separate mechanical indicator is used to indicate the position of the main contacts, colour red shall be used for the on position and green for the off position.		N/A
	The action of the mechanism shall not be influenced by the position of enclosures		P
	If the cover is used as a guiding means for push-button, it shall not be possible to remove this button from the outside		N/A
	Operating means securely fixed, not possible to remove them without a tool		P
	For the up-down operating means the contacts shall be closed by the up movement.		P
<b>8.1.3</b>	<b>Clearances and creepage distances and operation</b>		P
	The minimum required clearances and creepage distances are based on the CB being designed for operating in an environment with pollution degree 2		P
	Parts of PCBs connected to live parts and protected against pollution by the use of a type 2 protection according to IEC 60664-3 are exempted from this verification		N/A
	The insulating materials are classified into material groups on the basis of their comparative tracking index (CTI) according to IEC 60664-1		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	For clearances on printed wiring material, footnote 3 in Table F.2 of IEC 60664-1:2007 applies. For creepage distances on printed wiring material, the distances from Table F.4 of IEC 60664-1:2007 for pollution degree 1 can be applied only if protected with a coating meeting IEC 60664-3 requirements and tests		N/A
8.1.3.1	Clearances		P
	Compliance for item 1 in Table 4 is checked by measurement and by the test of 9.7.5.4. The test is carried out with samples not submitted to the humidity treatment described in 9.7.1		P
	Compliance as regards items 2 and 4 in Table 4 is checked by measurement and, if the clearances are reduced, by the tests of 9.7.5.2		P
	The clearances of items 2 and 4 (except accessible surface after installation) may be reduced provided that the measured clearances are not shorter than the minimum allowed in IEC 60664-1 for homogenous field conditions.		P
	In this case, compliance as regards items 2 and 4 is always checked by the test of 9.7.5.2		P
	Compliance as regards item 3 in Table 4 is checked by measurement		P
	Minimum clearances (see table 4)		P
	Clearances [mm] Uimp		--
	4 kV (see table 4) 2,5 kV (see table 4)	<input checked="" type="checkbox"/> <input type="checkbox"/>	--
		minimum clearances 4,0 [mm]	--
	1.between live parts (of the main circuits) which are separated when the CB is in off position .....	6,08 mm	P
	2.between live parts of different polarity.....	Single pole	P
	3.between circuits supplied from different sources, one of which being PELV or SELV .....	no such part	N/A
	4.between live parts and		P
	- accessible surfaces of operating means.....	26,94 mm	P
	- screws or other means for fixing covers .....	-	N/A
	- surface on which the base is mounted.....	26,32 mm	P
	- screws or other means for fixing the circuit breaker .....	-	N/A
	- metal covers or boxes .....	-	N/A
	- other accessible metal parts .....	26,94mm	P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- metal frames supporting the base (flush-type) .:	-	N/A
8.1.3.2	Creepage distances		P
	Compliance as regards items 1, 2, 3 and 4 of Table 4 is checked by measurement		
	Minimum creepage distances (see table 4)		
	Material group	<input type="checkbox"/> IIIb <input checked="" type="checkbox"/> IIIa <input type="checkbox"/> II <input type="checkbox"/> I	--
		minimum creepage distances 4,0[mm]	--
	1.between live parts (of the main circuits) which are separated when the CB is in off position .....	8,68 mm	P
	2.between live parts of different polarity.....	Single pole	P
	3.between circuits supplied from different sources, one of which being PELV or SELV .....	no such part	N/A
	4.between live parts and		P
	- accessible surfaces of operating means.....	32,38 mm	P
	- screws or other means for fixing covers .....	-	N/A
	- surface on which the base is mounted.....	30,88mm	P
	- screws or other means for fixing the circuit breaker .....	-	N/A
	- metal covers or boxes .....	-	N/A
	- other accessible metal parts .....	32,38mm	P
	- metal frames supporting the base (flush-type) .:		N/A
8.1.3.3	Solid insulation		P
	Compliance is checked by the tests according to 9.7.2, 9.7.3, 9.7.4 and 9.7.5, as applicable		P
<b>8.1.4</b>	<b>Screws, current-carrying parts and connections</b>		P
8.1.4.1	Connections, withstand mechanical stresses occurring in normal use		P
	Screws for mounting of the CB not of the thread-cutting type		N/A
	Test according to cl. 9.4:		P
	- 10 times (screw Ø / torque Nm)	Ø__mm__Nm (see table 11) Ø__mm__Nm	N/A
	- 5 times (screw Ø / torque Nm)	Ø_4,90__mm_2,0__Nm (see table 11) Ø__mm__Nm	P
	After test connections have not become loose nor electrical function impaired		P
8.1.4.2	Screws with a thread of insulating material ensured correct introduction		N/A

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
8.1.4.3	Electrical connection: contact pressure not transmitted through insulating material, unless there is sufficient resilience in the metallic parts		N/A
8.1.4.4	Current-carrying parts including parts intended for protective conductors, if any, shall be made of a metal having, under the conditions occurring in the equipment, mechanical strength, electrical conductivity and resistance to corrosion adequate for their intended use. Examples below:		P
	- copper		N/A
	- alloy 58% copper for worked cold parts	For contact	P
	- alloy 50% copper for other parts		N/A
	- other metal	Zn plated Steel for screw	P
	In case of using ferrous alloys or suitably coated ferrous alloys, compliance to resistance to corrosion is checked by a test of resistance to rusting (see 9.16).		N/A
	The requirements of this subclause do not apply to contacts, magnetic circuits, heater elements, bimetals, shunts, electronic components, including printed circuit board or to screws, nuts, washers, clamping plates, similar parts of terminals and parts of the test circuit		P
	Compliance is checked by inspection in accordance with the manufacturer's declaration		P
<b>8.1.5</b>	<b>Terminals for external conductors</b>		--
	Compliance is checked by inspection and by the tests as relevant for the type of connection:		--
	by tests of clause 9.5 for screw-type terminals		P
	by specific tests for plug-in or bolt-on CBs included in this document		N/A
	by the tescots of Annexes J, K		N/A
8.1.5.1	Terminals ensure the necessary contact pressure		P
9.5	Torque test:		P
	- torque (Nm); diameter (mm).....	4.90	--
	- torque (Nm); diameter (mm).....		--
	- torque (Nm); diameter (mm).....		--
	- max. cross-sectional area (mm <sup>2</sup> ).....	25	--
9.5.2	Pull test:		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Terminals shall be suitable for all types of conductors: rigid (solid or stranded) and flexible, unless otherwise specified by the manufacturer.		--
	Min. cross-section solid / stranded / flexible (mm <sup>2</sup> ).....:	1mm <sup>2</sup> for solid / flexible construction 1,5mm <sup>2</sup> for stranded construction	--
	Max. cross-section solid / stranded / flexible (mm <sup>2</sup> ).....:	6mm <sup>2</sup> for solid construction 25mm <sup>2</sup> for stranded construction 16mm <sup>2</sup> for flexible construction	--
	Torque <sup>2</sup> / <sub>3</sub> (Nm) .....	1,33	--
	Pull for 1 min solid / stranded / flexible (N).....:	50-100N	P
	During the test no noticeable move of conductor		P
9.5.3	Torque test:		P
	- torque <sup>2</sup> / <sub>3</sub> (Nm).....:	1,33Nm	--
	- min. cross-sectional area (mm <sup>2</sup> ).....:	1mm <sup>2</sup>	--
	- max. cross-sectional area (mm <sup>2</sup> ).....:	25mm <sup>2</sup>	--
	The conductor shows no undue damage nor severed strands		P
	Terminals have not worked loose and no damage		P
9.5.4	Terminals fitted with the largest cross-section area specified in Table 5, for stranded copper conductor.		P
	Max. cross-section stranded (mm <sup>2</sup> ).....:	25mm <sup>2</sup>	--
	Torque <sup>2</sup> / <sub>3</sub> (Nm) .....	1,33Nm	--
	After the test no strand of conductor escaped outside		P
8.1.5.2	Terminals allow the connection of conductors of the following cross-sectional areas: (table 5)		P


IEC 60898-1																														
Clause	Requirement + Test	Result - Remark	Verdict																											
	<p>Rated current (A)      Range of nominal cross sections to be clamped* (mm<sup>2</sup>)</p> <table border="1"> <thead> <tr> <th></th> <th>Rigid (solid or stranded) conductors</th> <th>Flexible conductors</th> </tr> </thead> <tbody> <tr> <td>≤ 13</td> <td>1 to 2,5</td> <td>1 to 2,5</td> </tr> <tr> <td>&gt; 13 ≤ 16</td> <td>1 to 4</td> <td>1 to 4</td> </tr> <tr> <td>&gt; 16 ≤ 25</td> <td>1,5 to 6</td> <td>1,5 to 6</td> </tr> <tr> <td>&gt; 25 ≤ 32</td> <td>2,5 to 10</td> <td>2,5 to 6</td> </tr> <tr> <td>&gt; 32 ≤ 50</td> <td>4 to 16</td> <td>4 to 10</td> </tr> <tr> <td>&gt; 50 ≤ 80</td> <td>10 to 25</td> <td>10 to 16</td> </tr> <tr> <td>&gt; 80 ≤ 100</td> <td>16 to 35</td> <td>16 to 25</td> </tr> <tr> <td>&gt; 100 ≤ 125</td> <td>24 to 50</td> <td>25 to 35</td> </tr> </tbody> </table>		Rigid (solid or stranded) conductors	Flexible conductors	≤ 13	1 to 2,5	1 to 2,5	> 13 ≤ 16	1 to 4	1 to 4	> 16 ≤ 25	1,5 to 6	1,5 to 6	> 25 ≤ 32	2,5 to 10	2,5 to 6	> 32 ≤ 50	4 to 16	4 to 10	> 50 ≤ 80	10 to 25	10 to 16	> 80 ≤ 100	16 to 35	16 to 25	> 100 ≤ 125	24 to 50	25 to 35		P
	Rigid (solid or stranded) conductors	Flexible conductors																												
≤ 13	1 to 2,5	1 to 2,5																												
> 13 ≤ 16	1 to 4	1 to 4																												
> 16 ≤ 25	1,5 to 6	1,5 to 6																												
> 25 ≤ 32	2,5 to 10	2,5 to 6																												
> 32 ≤ 50	4 to 16	4 to 10																												
> 50 ≤ 80	10 to 25	10 to 16																												
> 80 ≤ 100	16 to 35	16 to 25																												
> 100 ≤ 125	24 to 50	25 to 35																												
	*It is required that, for current ratings up to and including 50 A, terminals be designed to clamp solid conductors as well as rigid stranded conductors. Nevertheless, it is permitted that terminals for conductors having cross-sections from 1 mm <sup>2</sup> up to 6 mm <sup>2</sup> be designed to clamp solid conductors only.		N/A																											
	- or terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors according to Annex L.		N/A																											
8.1.5.3	Means for clamping the conductors in the terminals not serve to fix any other component (See test sub-clause 9.5)		P																											
8.1.5.4	Terminals for $I_N \leq 32$ A allow the connection of conductors without special preparation		P																											
8.1.5.5	Terminals shall have adequate mechanical strength; ISO thread or equivalent (See tests of sub-clause 9.4 and 9.5.2)		P																											
8.1.5.6	Clamping of conductor without damage to the conductor (See test of sub-clause 9.5.3)		P																											
8.1.5.7	Clamping of conductor between metal surfaces (See tests of sub-clause 9.4 and 9.5.2)		P																											
8.1.5.8	Conductor shall not slip-out when the clamping screw or nuts are tightened (See test of sub-clause 9.5.4)		P																											
8.1.5.9	Terminals shall be properly fixed. No work loose when the clamping screws or nuts are tightened or loosened (See test of sub-clause 9.4)		P																											
8.1.5.10	Clamping screws or nuts of terminals for protective conductors adequately secured against accidental loosening		N/A																											

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
8.1.5.11	Pillar terminals shall allow full insertion and reliable clamping of the conductor		N/A
8.1.5.12	Screws and nuts of terminals for external conductors shall be in engagement with a metal thread, and the screws shall not be the thread cutting type		P
<b>8.1.6</b>	<b>Non-interchangeability</b>		<b>N/A</b>
	For circuit-breakers intended to be mounted on bases forming a unit therewith (plug-in or screw-in type) it shall not be possible, without the aid of a tool, to replace a circuit-breaker when mounted as for normal use by another of the same make having a higher rated current, compliance is checked by inspection		N/A
<b>8.1.7</b>	<b>Mechanical mounting of plug-in circuit-breakers</b>		N/A
8.1.7.1	The mechanical mounting of plug-in circuit-breakers, the retention of which does not depend solely on their plug-in connection(s), shall be reliable and have adequate stability		N/A
8.1.7.2	Plug-in type circuit-breakers, the retention of which does not depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
8.1.7.3	Plug-in type circuit-breakers, the retention of which does depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
<b>8.14</b>	<b>Electromagnetic Immunity</b>		P
	Circuit-breakers for overcurrent protection for household and similar installations are not sensitive to normal electromagnetic disturbance and therefore no immunity tests are required		P
<b>8.15</b>	<b>Electromagnetic emission</b>		P
	Electromagnetic disturbance can only be generated by circuit-breakers for overcurrent protection for household and similar installations during occasional switching or automatic breaking operations. The duration of the disturbances is of the order of milliseconds		P
	The frequency, the level and the consequences of these emissions are considered as part of the normal electromagnetic environment of low-voltage installations. Therefore the requirements for electromagnetic emissions are deemed to be satisfied and no verifications are necessary		P

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
<b>8.2</b>	<b>Protection against electric shock</b>		P
	Live parts not accessible in normal use		P
	For CB, other than plug-in type, external parts, other than screws and other means for fixing covers, which are accessible shall be of insulating material		P
	Unless the live parts are within an internal enclosure of insulating material: Lining - reliable fixed, - adequate thickness and - mechanical strength		P
	Inlet openings for cables shall be in insulating material or be provided with bushings or similar devices in insulating material Such device - shall be reliable fixed - shall have adequate mechanical strength		N/A
	For plug-in CB, external parts, other than screws and other means for fixing covers, which are accessible shall be in insulating material		N/A
	Metallic operating means insulated from live parts		N/A
	Metal parts of the mechanism not accessible and insulated from accessible metal parts, metal frames (for flush-type), screws or other means for fixing the base		P
	Replacement of plug-in CB possible without touching live parts		N/A
	Lacquer or enamel not considered		N/A
<b>8.1.3</b>	<b>Creepage distances [mm] (see table 4)</b>		P
	Internal parts only	See above	N/A
<b>9.6</b>	<b>Test of protection against electric shock</b>		P
	This verification is applicable to those parts of circuit breakers which are exposed to the operator when mounted as for normal use		P
	Use of test finger so designed that each jointed can be turned through an angle of 90° with respect to the finger		P
	Circuit-breaker with enclosures of thermoplastic material are additional tested at 35 °C for 1 min with a force of 75 N		P
<b>8.10</b>	<b>Resistance to heat</b>		P
	CB sufficiently resistant to heat		P
<b>9.14</b>	<b>Test of resistance to heat</b>		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.14.1	Test:		P
	- without removable covers ..... 1 h (100 ± 2) °C		P
	- removable covers ..... 1 h (70 ± 2) °C		N/A
	After the test no access to live parts, marking still legible		P
9.14.2	Ball pressure test for external parts of insulating material (parts retaining current-carrying parts and parts of the protective circuit in position) T = 125°C Ø of impression ≤ 2 mm	Impression: 1,1mm for enclosure	P
9.14.3	Ball pressure test for external parts of insulating material (parts not retaining current-carrying parts and parts of the protective circuit in position) T = (70 ± 2)°C or T = ___ °C = (40 ± 2)°C + max. temperature rise of sub-clause 9.8 Ø of impression ≤ 2 mm		P
<b>8.12</b>	<b>Resistance to rusting</b>		<b>P</b>
	Ferrous parts adequately protected against rusting		P
<b>9.16</b>	<b>Test of resistance to rusting:</b>		<b>P</b>
	- 10 min immersed in a cold chemical degreaser such as methyl-chloroform or refined petrol		P
	- 10 min immersed in a 10% solution of chloride in water at 20°C		P
	- 10 min at 95% humidity at 20°C		P
	- 10 min at 100°C		P
	No sign of rust		P
	<b>TESTS „A<sub>2</sub>“ 3 samples For D63, 2P</b>	<b>A<sub>2-1</sub>    A<sub>2-2</sub>    A<sub>2-3</sub></b>	
<b>8.11</b>	<b>Resistance to abnormal heat and to fire</b>		<b>P</b>
	External parts of insulating material shall not ignite or spread fire under fault or overload conditions		P
<b>9.15</b>	<b>Resistance to abnormal heat and to fire</b>		<b>P</b>
	Test performed on a complete CB		P
	external parts retaining current-carrying parts and parts of the protective circuit in position ..... (960 ± 15)°C		P
	all other external parts ..... (650 ± 10)°C		M/A
	No visible flames, no sustained glowing, or		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	flames and glowing extinguish within 30 s after removal .....		P
	No ignition of tissue paper or scorching of the pinewood board		P
	<b>TESTS „A1“ 1 SAMPLE FOR D63, 4P</b>		--
<b>6</b>	<b>MARKING AND OTHER INFORMATION</b>		
	Circuit-breaker marked with:		--
	a) Manufacturer's name or trade mark.....	Trademark: CNC	P
	b) Type designation, catalogue number or other serial number .....	YCB9-63	P
	c) Rated voltage (V).....	400V~	P
	d) Rated current without symbol "A", preceded by the symbol of instantaneous tripping.....	D63	P
	e) Rated frequency (Hz) .....	50/60Hz	P
	f) Rated short circuit capacity (A) .....	6000A	P
	g) Wiring diagram	See copy of marking plate	P
	h) Ambient air temperature, if different from 30°C		N/A
	i) Degree of protection, if different from IP20		N/A
	j) For D-type circuit-breakers: the maximum instantaneous tripping current, if higher than 20 In see table 2)		N/A
	k) Rated impulse withstand voltage Uimp if it is 2,5 kV	4,0 kV	P
	l) Making and breaking capacity on an individual protected pole of multipole circuit-breakers (Icn1), if different from Icn		N/A
	Marking d) shall be readily visible when the CB is installed		P
	If, for small devices, the available space is insufficient, markings a), b), c), e), f), h), j) and l) may be put on the side or on the back of the CB		N/A

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	Marking g) may be on the inside of any cover which has to be removed in order to connect the supply wires but shall not be on a label loosely attached to the CB		N/A
	Any other information not marked shall be given in the manufacturer's documentation		P
	The suitability for isolation, which is provided by all circuit-breakers of this standard, may be indicated by the symbol on the device		P
	I <sup>2</sup> t characteristic (documentation)		N/A
	Symbols on supply and load terminal		N/A
	Terminal for neutral conductor N		N/A
	Earthing terminal if any (IEC 60417-5019)		N/A
	On - off position shall be clearly indicated - 0 I -		P
	For push-button CB the off push-button shall either be red or be marked with the symbol '0'		N/A
	Red not used for other push-button		N/A
	For CB with multiple current ratings, the maximum value is marked, the adjusted value indicated without ambiguity		N/A
	For rail-mounted circuit-breakers, appropriate rail(s) shall be indicated in the manufacturer's documentation		N/A
	Marking shall be indelible and easily legible (not on removable parts), 15 s with water, 15 s with hexane (see cl. 9.3)		P
<b>8.</b>	<b>REQUIREMENTS FOR CONSTRUCTION AND OPERATION</b>		
<b>8.1.1</b>	<b>General</b>		P
	Circuit-breakers shall be so designed and constructed that, in normal use, their performance is reliable and without danger to the user or surroundings		P
<b>8.1.2</b>	<b>Mechanism</b>		P
	The moving contact shall be mechanically coupled so that all poles make and break together, whether operated manually or automatically, even if an overload occurs on one pole only		P

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	The switched neutral shall close before and open after the protected pole (s)		N/A
	Neutral pole having adequate making and breaking capacity and CB with independent manual operation: all poles operate together including neutral pole		N/A
	CB shall have a trip free mechanism		P
	It shall be possible to switch the CB on and off by hand		P
	No intermediate position of the contacts		P
	Position of contacts shall be indicated		P
	Indication visible from the outside		P
	If the indication is on the actuating means, it shall, when released, automatically take up or stay in the position corresponding to that of the moving contacts; operating means shall have two different rest positions, except that, for automatic operation, a third distinct rest position may be provided		N/A
	If a separate mechanical indicator is used to indicate the position of the main contacts, colour red shall be used for the on position and green for the off position.		N/A
	The action of the mechanism shall not be influenced by the position of enclosures		P
	If the cover is used as a guiding means for push-button, it shall not be possible to remove this button from the outside		N/A
	Operating means securely fixed, not possible to remove them without a tool		P
	For the up-down operating means the contacts shall be closed by the up movement.		P
<b>8.1.3</b>	<b>Clearances and creepage distances and operation</b>		P
	The minimum required clearances and creepage distances are based on the CB being designed for operating in an environment with pollution degree 2		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Parts of PCBs connected to live parts and protected against pollution by the use of a type 2 protection according to IEC 60664-3 are exempted from this verification		N/A
	The insulating materials are classified into material groups on the basis of their comparative tracking index (CTI) according to IEC 60664-1		N/A
	For clearances on printed wiring material, footnote 3 in Table F.2 of IEC 60664-1:2007 applies. For creepage distances on printed wiring material, the distances from Table F.4 of IEC 60664-1:2007 for pollution degree 1 can be applied only if protected with a coating meeting IEC 60664-3 requirements and tests		N/A
8.1.3.1	Clearances		P
	Compliance for item 1 in Table 4 is checked by measurement and by the test of 9.7.5.4. The test is carried out with samples not submitted to the humidity treatment described in 9.7.1		P
	Compliance as regards items 2 and 4 in Table 4 is checked by measurement and, if the clearances are reduced, by the tests of 9.7.5.2		P
	The clearances of items 2 and 4 (except accessible surface after installation) may be reduced provided that the measured clearances are not shorter than the minimum allowed in IEC 60664-1 for homogenous field conditions.		P
	In this case, compliance as regards items 2 and 4 is always checked by the test of 9.7.5.2		P
	Compliance as regards item 3 in Table 4 is checked by measurement		P
	Minimum clearances (see table 4)		P
	Clearances [mm] Uimp		--
	4 kV (see table 4) 2,5 kV (see table 4)	<input checked="" type="checkbox"/> <input type="checkbox"/>	--
		minimum clearances 4,0 [mm]	--
	1.between live parts (of the main circuits) which are separated when the CB is in off position ..... :	6,08 mm	P
	2.between live parts of different polarity..... :	9,14 mm	P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	3.between circuits supplied from different sources, one of which being PELV or SELV .....	no such part	N/A
	4.between live parts and		P
	- accessible surfaces of operating means.....	26,94 mm	P
	- screws or other means for fixing covers .....	-	N/A
	- surface on which the base is mounted.....	26,32 mm	P
	- screws or other means for fixing the circuit breaker .....	-	N/A
	- metal covers or boxes .....	-	N/A
	- other accessible metal parts .....	26,94mm	P
	- metal frames supporting the base (flush-type) ..	-	N/A
8.1.3.2	Creepage distances		P
	Compliance as regards items 1, 2, 3 and 4 of Table 4 is checked by measurement		
	Minimum creepage distances (see table 4)		
	Material group	<input type="checkbox"/> IIIb <input checked="" type="checkbox"/> IIIa <input type="checkbox"/> II <input type="checkbox"/> I	--
		minimum creepage distances 4,0[mm]	--
	1.between live parts (of the main circuits) which are separated when the CB is in off position .....	8,68 mm	P
	2.between live parts of different polarity.....	17,82	P
	3.between circuits supplied from different sources, one of which being PELV or SELV .....	no such part	N/A
	4.between live parts and		P
	- accessible surfaces of operating means.....	32,38 mm	P
	- screws or other means for fixing covers .....	-	N/A
	- surface on which the base is mounted.....	30,88mm	P
	- screws or other means for fixing the circuit breaker .....	-	N/A
	- metal covers or boxes .....	-	N/A
	- other accessible metal parts .....	32,38mm	P
	- metal frames supporting the base (flush-type) ..		N/A
8.1.3.3	Solid insulation		P
	Compliance is checked by the tests according to 9.7.2, 9.7.3, 9.7.4 and 9.7.5, as applicable		P
<b>8.1.4</b>	<b>Screws, current-carrying parts and connections</b>		<b>P</b>
8.1.4.1	Connections, withstand mechanical stresses occurring in normal use		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Screws for mounting of the CB not of the thread-cutting type		N/A
	Test according to cl. 9.4:		P
	- 10 times (screw Ø / torque Nm)	Ø__mm__Nm (see table 11) Ø__mm__Nm	N/A
	- 5 times (screw Ø / torque Nm)	Ø_4,90__mm_2,0__Nm (see table 11) Ø__mm__Nm	P
	After test connections have not become loose nor electrical function impaired		P
8.1.4.2	Screws with a thread of insulating material ensured correct introduction		N/A
8.1.4.3	Electrical connection: contact pressure not transmitted through insulating material, unless there is sufficient resilience in the metallic parts		N/A
8.1.4.4	Current-carrying parts including parts intended for protective conductors, if any, shall be made of a metal having, under the conditions occurring in the equipment, mechanical strength, electrical conductivity and resistance to corrosion adequate for their intended use. Examples below:		P
	- copper		N/A
	- alloy 58% copper for worked cold parts	For contact	P
	- alloy 50% copper for other parts		N/A
	- other metal	Zn plated Steel for screw	P
	In case of using ferrous alloys or suitably coated ferrous alloys, compliance to resistance to corrosion is checked by a test of resistance to rusting (see 9.16).		N/A
	The requirements of this subclause do not apply to contacts, magnetic circuits, heater elements, bimetals, shunts, electronic components, including printed circuit board or to screws, nuts, washers, clamping plates, similar parts of terminals and parts of the test circuit		P
	Compliance is checked by inspection in accordance with the manufacturer's declaration		P
<b>8.1.5</b>	<b>Terminals for external conductors</b>		--
	Compliance is checked by inspection and by the tests as relevant for the type of connection:		--
	by tests of clause 9.5 for screw-type terminals		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	by specific tests for plug-in or bolt-on CBs included in this document		N/A
	by the tescots of Annexes J, K		N/A
8.1.5.1	Terminals ensure the necessary contact pressure		P
9.5	Torque test:		P
	- torque (Nm); diameter (mm).....:	4.90	--
	- torque (Nm); diameter (mm).....:		--
	- torque (Nm); diameter (mm).....:		--
	- max. cross-sectional area (mm <sup>2</sup> ).....:	25	--
9.5.2	Pull test:		P
	Terminals shall be suitable for all types of conductors: rigid (solid or stranded) and flexible, unless otherwise specified by the manufacturer.		--
	Min. cross-section solid / stranded / flexible (mm <sup>2</sup> ).....:	1mm <sup>2</sup> for solid / flexible construction 1,5mm <sup>2</sup> for stranded construction	--
	Max. cross-section solid / stranded / flexible (mm <sup>2</sup> ).....:	6mm <sup>2</sup> for solid construction 25mm <sup>2</sup> for stranded construction 16mm <sup>2</sup> for flexible construction	--
	Torque <sup>2</sup> / <sub>3</sub> (Nm) .....	1,33	--
	Pull for 1 min solid / stranded / flexible (N).....:	50-100N	P
	During the test no noticeable move of conductor		P
9.5.3	Torque test:		P
	- torque <sup>2</sup> / <sub>3</sub> (Nm).....:	1,33Nm	--
	- min. cross-sectional area (mm <sup>2</sup> ).....:	1mm <sup>2</sup>	--
	- max. cross-sectional area (mm <sup>2</sup> ).....:	25mm <sup>2</sup>	--
	The conductor shows no undue damage nor severed strands		P
	Terminals have not worked loose and no damage		P
9.5.4	Terminals fitted with the largest cross-section area specified in Table 5, for stranded copper conductor.		P
	Max. cross-section stranded (mm <sup>2</sup> ).....:	25mm <sup>2</sup>	--
	Torque <sup>2</sup> / <sub>3</sub> (Nm) .....	1,33Nm	--

IEC 60898-1																																
Clause	Requirement + Test	Result - Remark	Verdict																													
	After the test no strand of conductor escaped outside		P																													
8.1.5.2	Terminals allow the connection of conductors of the following cross-sectional areas: (table 5)		P																													
	<table border="1"> <thead> <tr> <th rowspan="2">Rated current (A) sections</th> <th colspan="2">Range of nominal cross sections to be clamped* (mm<sup>2</sup>)</th> </tr> <tr> <th>Rigid (solid or stranded) conductors</th> <th>Flexible conductors</th> </tr> </thead> <tbody> <tr> <td>≤ 13</td> <td>1 to 2,5</td> <td>1 to 2,5</td> </tr> <tr> <td>&gt; 13 ≤ 16</td> <td>1 to 4</td> <td>1 to 4</td> </tr> <tr> <td>&gt; 16 ≤ 25</td> <td>1,5 to 6</td> <td>1,5 to 6</td> </tr> <tr> <td>&gt; 25 ≤ 32</td> <td>2,5 to 10</td> <td>2,5 to 6</td> </tr> <tr> <td>&gt; 32 ≤ 50</td> <td>4 to 16</td> <td>4 to 10</td> </tr> <tr> <td>&gt; 50 ≤ 80</td> <td>10 to 25</td> <td>10 to 16</td> </tr> <tr> <td>&gt; 80 ≤ 100</td> <td>16 to 35</td> <td>16 to 25</td> </tr> <tr> <td>&gt; 100 ≤ 125</td> <td>24 to 50</td> <td>25 to 35</td> </tr> </tbody> </table>	Rated current (A) sections	Range of nominal cross sections to be clamped* (mm <sup>2</sup> )		Rigid (solid or stranded) conductors	Flexible conductors	≤ 13	1 to 2,5	1 to 2,5	> 13 ≤ 16	1 to 4	1 to 4	> 16 ≤ 25	1,5 to 6	1,5 to 6	> 25 ≤ 32	2,5 to 10	2,5 to 6	> 32 ≤ 50	4 to 16	4 to 10	> 50 ≤ 80	10 to 25	10 to 16	> 80 ≤ 100	16 to 35	16 to 25	> 100 ≤ 125	24 to 50	25 to 35		P
Rated current (A) sections	Range of nominal cross sections to be clamped* (mm <sup>2</sup> )																															
	Rigid (solid or stranded) conductors	Flexible conductors																														
≤ 13	1 to 2,5	1 to 2,5																														
> 13 ≤ 16	1 to 4	1 to 4																														
> 16 ≤ 25	1,5 to 6	1,5 to 6																														
> 25 ≤ 32	2,5 to 10	2,5 to 6																														
> 32 ≤ 50	4 to 16	4 to 10																														
> 50 ≤ 80	10 to 25	10 to 16																														
> 80 ≤ 100	16 to 35	16 to 25																														
> 100 ≤ 125	24 to 50	25 to 35																														
	*It is required that, for current ratings up to and including 50 A, terminals be designed to clamp solid conductors as well as rigid stranded conductors. Nevertheless, it is permitted that terminals for conductors having cross-sections from 1 mm <sup>2</sup> up to 6 mm <sup>2</sup> be designed to clamp solid conductors only.		N/A																													
	- or terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors according to Annex L.		N/A																													
8.1.5.3	Means for clamping the conductors in the terminals not serve to fix any other component (See test sub-clause 9.5)		P																													
8.1.5.4	Terminals for $I_N \leq 32$ A allow the connection of conductors without special preparation		P																													
8.1.5.5	Terminals shall have adequate mechanical strength; ISO thread or equivalent (See tests of sub-clause 9.4 and 9.5.2)		P																													
8.1.5.6	Clamping of conductor without damage to the conductor (See test of sub-clause 9.5.3)		P																													
8.1.5.7	Clamping of conductor between metal surfaces (See tests of sub-clause 9.4 and 9.5.2)		P																													
8.1.5.8	Conductor shall not slip-out when the clamping screw or nuts are tightened (See test of sub-clause 9.5.4)		P																													
8.1.5.9	Terminals shall be properly fixed. No work loose when the clamping screws or nuts are tightened or loosened (See test of sub-clause 9.4)		P																													

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
8.1.5.10	Clamping screws or nuts of terminals for protective conductors adequately secured against accidental loosening		N/A
8.1.5.11	Pillar terminals shall allow full insertion and reliable clamping of the conductor		N/A
8.1.5.12	Screws and nuts of terminals for external conductors shall be in engagement with a metal thread, and the screws shall not be the thread cutting type		P
<b>8.1.6</b>	<b>Non-interchangeability</b>		<b>N/A</b>
	For circuit-breakers intended to be mounted on bases forming a unit therewith (plug-in or screw-in type) it shall not be possible, without the aid of a tool, to replace a circuit-breaker when mounted as for normal use by another of the same make having a higher rated current, compliance is checked by inspection		N/A
<b>8.1.7</b>	<b>Mechanical mounting of plug-in circuit-breakers</b>		N/A
8.1.7.1	The mechanical mounting of plug-in circuit-breakers, the retention of which does not depend solely on their plug-in connection(s), shall be reliable and have adequate stability		N/A
8.1.7.2	Plug-in type circuit-breakers, the retention of which does not depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
8.1.7.3	Plug-in type circuit-breakers, the retention of which does depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
<b>8.14</b>	<b>Electromagnetic Immunity</b>		P
	Circuit-breakers for overcurrent protection for household and similar installations are not sensitive to normal electromagnetic disturbance and therefore no immunity tests are required		P
<b>8.15</b>	<b>Electromagnetic emission</b>		P
	Electromagnetic disturbance can only be generated by circuit-breakers for overcurrent protection for household and similar installations during occasional switching or automatic breaking operations. The duration of the disturbances is of the order of milliseconds		P

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	The frequency, the level and the consequences of the these emissions are considered as part of the normal eletromagnetic enviroment of low-voltage installations. Therefore the requirements for electromagnetic emssions are deemed to be satisfied and no verifications is necessary		P
<b>8.2</b>	<b>Protection against electric shock</b>		P
	Live parts not accessible in normal use		P
	For CB, other than plug-in type, external parts, other than screws and other means for fixing covers, which are accessible shall be of insulating material		P
	Unless the live parts are within an internal enclosure of insulating material: Lining - reliable fixed, - adequate thickness and - mechanical strength		P
	Inlet openings for cables shall be in insulating material or be provided with bushings or similar devices in insulating material Such device - shall be reliable fixed - shall have adequate mechanical strength		N/A
	For plug-in CB, external parts, other than screws and other means for fixing covers, which are accessible shall be in insulating material		N/A
	Metallic operating means insulated from live parts		N/A
	Metal parts of the mechanism not accessible and insulated from accessible metal parts, metal frames (for flush-type), screws or other means for fixing the base		P
	Replacement of plug-in CB possible without touching live parts		N/A
	Lacquer or enamel not considered		N/A
<b>8.1.3</b>	<b>Creepage distances [mm] (see table 4)</b>		P
	Internal parts only	See above	N/A
<b>9.6</b>	<b>Test of protection against electric shock</b>		P
	This verification is applicable to those parts of circuit breakers which are exposed to the operator when mounted as for normal use		P
	Use of test finger so designed that each jointed can be turned through an angle of 90° with respect to the finger		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Circuit-breaker with enclosures of thermoplastic material are additional tested at 35 °C for 1 min with a force of 75 N		P
<b>8.10</b>	<b>Resistance to heat</b>		P
	CB sufficiently resistant to heat		P
<b>9.14</b>	<b>Test of resistance to heat</b>		P
9.14.1	Test:		P
	- without removable covers ..... 1 h (100 ± 2) °C		P
	- removable covers ..... 1 h (70 ± 2) °C		N/A
	After the test no access to live parts, marking still legible		P
9.14.2	Ball pressure test for external parts of insulating material (parts retaining current-carrying parts and parts of the protective circuit in position) T = 125°C Ø of impression ≤ 2 mm	Impression: 1,1mm for enclosure	P
9.14.3	Ball pressure test for external parts of insulating material (parts not retaining current-carrying parts and parts of the protective circuit in position) T = (70 ± 2)°C or T = ___ °C = (40 ± 2)°C + max. temperature rise of sub-clause 9.8 Ø of impression ≤ 2 mm		P
<b>8.12</b>	<b>Resistance to rusting</b>		<b>P</b>
	Ferrous parts adequately protected against rusting		P
<b>9.16</b>	<b>Test of resistance to rusting:</b>		P
	- 10 min immersed in a cold chemical degreaser such as methyl-chloroform or refined petrol		P
	- 10 min immersed in a 10% solution of chloride in water at 20°C		P
	- 10 min at 95% humidity at 20°C		P
	- 10 min at 100°C		P
	No sign of rust		P
	<b>TESTS „A<sub>2</sub>“ 3 samples For D63, 4P</b>	<b>A<sub>2-1</sub></b> <b>A<sub>2-2</sub></b> <b>A<sub>2-3</sub></b>	
<b>8.11</b>	<b>Resistance to abnormal heat and to fire</b>		<b>P</b>
	External parts of insulating material shall not ignite or spread fire under fault or overload conditions		P
<b>9.15</b>	<b>Resistance to abnormal heat and to fire</b>		<b>P</b>
	Test performed on a complete CB		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	external parts retaining current-carrying parts and parts of the protective circuit in position ..... (960 ± 15)°C		P
	all other external parts ..... (650 ± 10)°C		M/A
	No visible flames, no sustained glowing, or		N/A
	flames and glowing extinguish within 30 s after removal .....		P
	No ignition of tissue paper or scorching of the pinewood board		P

	TESTS „B“ 3 samples D63; 1POLE	B <sub>1</sub>	B <sub>2</sub>	B <sub>3</sub>	
<b>8.3</b>	<b>Dielectric properties and isolating capability</b>				P
8.3.1	CB shall have adequate dielectric properties and shall ensure isolation:				P
8.3.2	Dielectric strength at power frequency				P
	Compliance is checked by the tests 9.7.1, 9.7.2 and 9.7.3 on circuit-breaker in new condition				P
8.3.3	Isolating capability				P
	Circuit-breakers shall be suitable for isolation. Compliance is checked by the verification of compliance with the minimum clearances and creepage distances of item 1 of table 4 and by tests of 9.7.5.1 and 9.7.5.3.				P
8.3.4	Dielectric strength at rated impulse withstand voltage (Uimp)				
	Circuit-breakers shall adequately withstand impulse voltages. Compliance is checked by the tests of 9.7.5.2.				P
<b>9.7</b>	<b>Test of dielectric properties and isolating capability</b>				P
9.7.5.4	Verification of resistance of the insulation of open contact and basic insulation against an impulse voltage in normal conditions				P
	These tests are not preceded by the humidity treatment described in 9.7.1.				P
	The test is carried out on an CB fixed on a metal support				P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2µs, and a time to half-value of 50µs				P
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.				P
	rated impulse withstand voltage [kV]:	4,0kV			--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	sea level of test laboratory [m]:	5 m	--
	test voltage (acc. Table 15) [kV]:	6,2kV	--
9.7.5.4.2	CB in open position (contacts in open position)		P
	The impulses are applied between:		--
	the line terminals connected together and the load terminals connected together		P
9.7.5.4.3	CB in closed position		P
	A first series of tests is made applying the impulse voltage between the phase pole(s) and the neutral pole (or path) connected together and the metal support connected to the terminal(s) intended for the protective conductor(s), if any		P
	A second series of tests is made applying the impulse voltage between the phase pole(s), connected together, and the neutral pole (or path) of the CB		P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		P
	no disruptive discharges during the test		P
9.7.1	Resistance to humidity		P
9.7.1.1	Preparation of the circuit-breaker for test		P
	Inlet openings, if any, are left open; if knock-outs are provided, one of them is opened.		N/A
9.7.1.2	Test conditions		P
	The humidity treatment is carried out in humidity cabinet 91% to 95% and the temperature of the air between 20 °C and 30 °C	Rf = 93...94 % T = 21,5...22,5 °C	P
9.7.1.3	Test procedure.		P
	The sample is kept in the cabinet for 48 h.		P
9.7.1.4	Conditions of the circuit breaker after the tests.		P
	The sample show no damage within the meaning of this standard and shall withstand the tests of 9.7.2 and 9.7.3, 9.7.4 and 9.7.5.2		P
9.7.2	Insulation resistance of the main circuit		P
9.7.2	After an interval between 30 min and 60 min flowing this treatment, the insulation resistance is measured 5 s after application of a d.c. voltage of approximately 500 V, consecutively as follows:	[MΩ]    [MΩ]    [MΩ]	P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	a) In off-position, between the terminals which are electrically connected together when the circuit-breaker is in the closed position $\geq 2 \text{ M}\Omega$		P
	b) in off-position, between each pole in turn and the others connected together $\geq 2 \text{ M}\Omega$		N/A
	c) in on-position, between all poles connected together and the frame $\geq 5 \text{ M}\Omega$		P
	d) between metal parts of mechanism and the frame $\geq 5 \text{ M}\Omega$		N/A
	e) between the frame and metal foil in contact with the inner surface of the internal enclosure or lining of insulating material $\geq 5 \text{ M}\Omega$		N/A
9.7.3	Dielectric strength of the main circuit		P
	After the circuit-breakers have passed the tests of 9.7.2 the test voltage specified is applied for 1 min between the parts indicated in 9.7.2		P
	a) 2000 V		P
	b) 2000 V		N/A
	c) 2000 V		P
	d) 2000 V		N/A
	e) 2500 V		N/A
	No flashover or breakdown		P
9.7.4	Insulation resistance and dielectric strength of the auxiliary circuits		N/A
	Insulation resistance of auxiliary circuits measured with 500 V DC after 1 min:		--
	1) between all auxiliary circuits and the frame ( $\text{M}\Omega$ ) $\geq 2 \text{ M}\Omega$		N/A
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together ( $\text{M}\Omega$ ) $\geq 2 \text{ M}\Omega$		N/A
	Dielectric strength of auxiliary circuits measured with an AC voltage at rated frequency for 1 min:		--
	Rated voltage of auxiliary circuits (a.c. or d.c.)	Test voltage (V)	V
	$\leq 30$	600	
	$> 30 \leq 50$	1000	
	$> 50 \leq 110$	1500	
	$> 110 \leq 250$	2000	
	$> 250 \leq 500$	2500	
	1) between all auxiliary circuits and the frame		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together		N/A
	No flashover or perforation		N/A
9.7.5.1	General testing procedure for the impulse withstand voltage tests		P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2 $\mu$ s, and a time to half-value of 50 $\mu$ s		P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		P
	The surge impedance of the test apparatus 500 $\Omega$ and surge protective devices disconnected before testing or		P
	When carrying out tests on a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), an impulse generator with a virtual impedance of 2 $\Omega$ shall be used		P
	The shape of the impulses is adjusted with the circuit-breaker under test connected to the impulse generator. For this purpose, appropriate voltage dividers and voltage sensors shall be used		P
	For a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), the shape of the impulses is adjusted without connection of the CB to the impulse generator		P
9.7.5.2	Verification of clearances with the impulse withstand voltage		N/A
	If the measurement of clearances of items 2 and 4 in Table 4 shows a reduction of the required length, this test applies.		N/A
	The test is carried out on an CB fixed on a metal support and being in the closed position		N/A
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2 $\mu$ s, and a time to half-value of 50 $\mu$ s		N/A
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	test performed with:		--
	-surge impedance of the test apparatus $\leq 500\Omega$ and surge protective devices disconnected before testing or		N/A
	-hybrid generator with an surge impedance of 2 $\Omega$ and surge protective devices not disconnected before testing		N/A
	rated impulse withstand voltage [kV]:		--
	see level of test laboratory [m]:		--
	test voltage (acc. Table 14) [kV]:		--
	A first series of tests is made applying the impulse voltage between the phase pole(s) and the neutral pole (or path) connected together and the metal support connected to the terminal(s) intended for the protective conductor(s), if any		N/A
	A second series of tests is made applying the impulse voltage between the phase pole(s), connected together, and the neutral pole (or path) of the CB		N/A
	A third series of tests is made applying the impulse voltage between (and not tested during the two first sequences described here above):		--
	b) between each pole and the others connected together		-
	c) between all poles connected together and the frame		N/A
	d) between metal parts of the mechanism and the frame		N/A
	e) between the frame and a metal foil in contact with the inner surface of the lining of insulating material		N/A
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		N/A
	no disruptive discharges during the test		P
<b>8.4</b>	<b>Temperature rise</b>		P
	Temperature rise does not exceed the limiting values stated in table 6:	sect. ___16___ mm <sup>2</sup>	P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.8.2	Test current: $I_N$ = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	$I_N = \underline{63} \text{ A}$			P
	Ambient air temperature .....	$T_{amb} = \underline{23,2} \text{ °C}$			P
	Parts ..... Temperature rise [K]	[K]	[K]	[K]	P
	L1	31,4	32,4	29,7	P
	L2	35,4	31,1	31,2	
	Terminals for external connections .....60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles .....40 K	9,2	9,9	9,5	P
	External metallic parts of operating means ...25 K				P
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface .....60 K	13,5	14,2	13,8	P
9.8.5	Measurement of power losses	$B_1$	$B_2$	$B_3$	P
	Power loss do not exceed the values stated in table 8				P
	Test current: $I_N = 63 \text{ A}$ (reach the steady state value)				P
	Loaded one pole after the other				P
	Max. power loss : $\underline{13} \text{ W}$	W	W	W	P
	L1	6,06	5,69	5,81	P
	L2	-	-	-	
	L3	-	-	-	
	L4(N)	-	-	-	
<b>8.5</b>	<b>Uninterrupted duty</b>				P
	Circuit-breakers operate reliable even after long service				P
<b>9.9</b>	<b>28 day test</b>				P
	28 cycles - 21 h with current - 3 h without current Cross-sectional area. $\underline{16} \text{ mm}^2$	$I_N = \underline{63} \text{ A}$			P
	During the test no tripping during the last period, temperature rise shall be measured				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Ambient air temperature.....	23,2°C			P
	Parts ..... Temperature rise [K]	[K]	[K]	[K]	--
	L1	32,2	32,8	30,5	P
	L2	34,7	31,7	31,4	
	Terminals for external connections .....				P
	The temperature rise does not exceed the value measured during the temperature rise test (sub-clause 9.8) by more than 15 K				P
	Test current 1,45 I <sub>N</sub> =91,35 A	91,4A			P
	- Tripping within	[s]	[s]	[s]	P
	- 1h (≤ 63 A)	1min33s	1min29s	1min18s	P
	- 2h (> 63 A)				N/A

	TESTS „B“ 3 samples D63; 4POLE	B <sub>1</sub>	B <sub>2</sub>	B <sub>3</sub>	
<b>8.3</b>	<b>Dielectric properties and isolating capability</b>				P
8.3.1	CB shall have adequate dielectric properties and shall ensure isolation:				P
8.3.2	Dielectric strength at power frequency				P
	Compliance is checked by the tests 9.7.1, 9.7.2 and 9.7.3 on circuit-breaker in new condition				P
8.3.3	Isolating capability				P
	Circuit-breakers shall be suitable for isolation. Compliance is checked by the verification of compliance with the minimum clearances and creepage distances of item 1 of table 4 and by tests of 9.7.5.1 and 9.7.5.3.				P
8.3.4	Dielectric strength at rated impulse withstand voltage (U <sub>imp</sub> )				
	Circuit-breakers shall adequately withstand impulse voltages. Compliance is checked by the tests of 9.7.5.2.				P
<b>9.7</b>	<b>Test of dielectric properties and isolating capability</b>				P
9.7.5.4	Verification of resistance of the insulation of open contact and basic insulation against an impulse voltage in normal conditions				P
	These tests are not preceded by the humidity treatment described in 9.7.1.				P
	The test is carried out on an CB fixed on a metal support				P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2μs, and a time to half-value of 50μs				P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.		P
	rated impulse withstand voltage [kV]:	4,0kV	--
	sea level of test laboratory [m]:	5 m	--
	test voltage (acc. Table 15) [kV]:	6,2kV	--
9.7.5.4.2	CB in open position (contacts in open position)		P
	The impulses are applied between:		--
	the line terminals connected together and the load terminals connected together		P
9.7.5.4.3	CB in closed position		P
	A first series of tests is made applying the impulse voltage between the phase pole(s) and the neutral pole (or path) connected together and the metal support connected to the terminal(s) intended for the protective conductor(s), if any		P
	A second series of tests is made applying the impulse voltage between the phase pole(s), connected together, and the neutral pole (or path) of the CB		P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		P
	no disruptive discharges during the test		P
9.7.1	Resistance to humidity		P
9.7.1.1	Preparation of the circuit-breaker for test		P
	Inlet openings, if any, are left open; if knock-outs are provided, one of them is opened.		N/A
9.7.1.2	Test conditions		P
	The humidity treatment is carried out in humidity cabinet 91% to 95% and the temperature of the air between 20 °C and 30 °C	Rf = 93...94 % T = 21,5...22,5 °C	P
9.7.1.3	Test procedure.		P
	The sample is kept in the cabinet for 48 h.		P
9.7.1.4	Conditions of the circuit breaker after the tests.		P
	The sample show no damage within the meaning of this standard and shall withstand the tests of 9.7.2 and 9.7.3, 9.7.4 and 9.7.5.2		P
9.7.2	Insulation resistance of the main circuit		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.7.2	After an interval between 30 min and 60 min flowing this treatment, the insulation resistance is measured 5 s after application of a d.c. voltage of approximately 500 V, consecutively as follows:	[MΩ] [MΩ] [MΩ]	P
	a) In off-position, between the terminals which are electrically connected together when the circuit-breaker is in the closed position $\geq 2 \text{ M}\Omega$		P
	b) in off-position, between each pole in turn and the others connected together $\geq 2 \text{ M}\Omega$		N/A
	c) in on-position, between all poles connected together and the frame $\geq 5 \text{ M}\Omega$		P
	d) between metal parts of mechanism and the frame $\geq 5 \text{ M}\Omega$		N/A
	e) between the frame and metal foil in contact with the inner surface of the internal enclosure or lining of insulating material $\geq 5 \text{ M}\Omega$		N/A
9.7.3	Dielectric strength of the main circuit		P
	After the circuit-breakers have passed the tests of 9.7.2 the test voltage specified is applied for 1 min between the parts indicated in 9.7.2		P
	a) 2000 V		P
	b) 2000 V		P
	c) 2000 V		P
	d) 2000 V		N/A
	e) 2500 V		N/A
	No flashover or breakdown		P
9.7.4	Insulation resistance and dielectric strength of the auxiliary circuits		N/A
	Insulation resistance of auxiliary circuits measured with 500 V DC after 1 min:		--
	1) between all auxiliary circuits and the frame ( $\text{M}\Omega$ ) $\geq 2 \text{ M}\Omega$		N/A
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together ( $\text{M}\Omega$ ) $\geq 2 \text{ M}\Omega$		N/A
	Dielectric strength of auxiliary circuits measured with an AC voltage at rated frequency for 1 min:		--

IEC 60898-1				
Clause	Requirement + Test	Result - Remark	Verdict	
	Rated voltage of auxiliary circuits (a.c. or d.c.)	Test voltage (V)	V	--
	≤ 30	600		
	> 30 ≤ 50	1000		
	> 50 ≤ 110	1500		
	> 110 ≤ 250	2000		
	> 250 ≤ 500	2500		
	1) between all auxiliary circuits and the frame			N/A
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together			N/A
	No flashover or perforation			N/A
9.7.5.1	General testing procedure for the impulse withstand voltage tests			P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2μs, and a time to half-value of 50μs			P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.			P
	The surge impedance of the test apparatus 500Ω and surge protective devices disconnected before testing or			P
	When carrying out tests on a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), an impulse generator with a virtual impedance of 2Ω shall be used			P
	The shape of the impulses is adjusted with the circuit-breaker under test connected to the impulse generator. For this purpose, appropriate voltage dividers and voltage sensors shall be used			P
	For a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), the shape of the impulses is adjusted without connection of the CB to the impulse generator			P
9.7.5.2	Verification of clearances with the impulse withstand voltage			N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	If the measurement of clearances of items 2 and 4 in Table 4 shows a reduction of the required length, this test applies.		N/A
	The test is carried out on an CB fixed on a metal support and being in the closed position		N/A
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2 $\mu$ s, and a time to half-value of 50 $\mu$ s		N/A
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.		N/A
	test performed with:		--
	-surge impedance of the test apparatus $\leq 500\Omega$ and surge protective devices disconnected before testing or		N/A
	-hybrid generator with an surge impedance of 2 $\Omega$ and surge protective devices not disconnected before testing		N/A
	rated impulse withstand voltage [kV]:	4,0kV	--
	see level of test laboratory [m]:	5m	--
	test voltage (acc. Table 14) [kV]:	U <sub>test</sub> =4,97 kV	--
	A first series of tests is made applying the impulse voltage between the phase pole(s) and the neutral pole (or path) connected together and the metal support connected to the terminal(s) intended for the protective conductor(s), if any		N/A
	A second series of tests is made applying the impulse voltage between the phase pole(s), connected together, and the neutral pole (or path) of the CB		N/A
	A third series of tests is made applying the impulse voltage between (and not tested during the two first sequences described here above):		--
	b) between each pole and the others connected together		-
	c) between all poles connected together and the frame		P
	d) between metal parts of the mechanism and the frame		P
	e) between the frame and a metal foil in contact with the inner surface of the lining of insulating material		N/A

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.				N/A	
	no disruptive discharges during the test				P	
<b>8.4</b>	<b>Temperature rise</b>				P	
	Temperature rise does not exceed the limiting values stated in table 6:	sect. __16__ mm <sup>2</sup>			P	
9.8.2	Test current: I <sub>N</sub> = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	I <sub>N</sub> = _63_ A			P	
	Ambient air temperature .....	T <sub>amb</sub> = __23,3__ °C			P	
	Parts .....	Temperature rise [K]	[K]	[K]	[K]	P
	L1	44,1	39,1	38,1	P	
	L2	56,8	41,7	45,7		
		58,3	44,7	47,5		
		45,3	41,9	47,3		
		39,7	35,4	37,1		
		42,6	41,4	42,4		
		52,6	47,1	39,7		
		40,9	36,7	38,7		
	Terminals for external connections .....60 K				P	
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles .....40 K	18,9	19,3	19,2	P	
	External metallic parts of operating means ...25 K	-	-	-	P	
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	24,6	24,9	24,8	P	
9.8.5	Measurement of power losses	B <sub>1</sub>	B <sub>2</sub>	B <sub>3</sub>	P	
	Power loss do not exceed the values stated in table 8				P	
	Test current: I <sub>N</sub> =63 A (reach the steady state value)				P	

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Loaded one pole after the other				P
	Max. power loss : ____13__ W	W	W	W	P
	L1	5,99	5,83	5,95	P
	L2	6,17	5,79	6,21	
	L3	6,68	5,95	6,49	
	L4(N)	6,16	5,69	5,85	
<b>8.5</b>	<b>Uninterrupted duty</b>				P
	Circuit-breakers operate reliable even after long service				P
<b>9.9</b>	<b>28 day test</b>				P
	28 cycles - 21 h with current - 3 h without current Cross-sectional area. __16__ mm <sup>2</sup>	I <sub>N</sub> = __63__ A			P
	During the test no tripping during the last period, temperature rise shall be measured				P
	Ambient air temperature..... :	23,0°C			P
	Parts ..... Temperature rise [K]	[K]	[K]	[K]	--
	L1	44,8	39,8	38,5	P
	L2	56,9	41,9	45,9	
	L3	58,5	45,3	48,2	
	L4	45,7	42,4	48,0	
	L5	40,2	35,9	39,5	
	L6	42,3	41,8	42,9	
	L7	52,9	47,7	39,5	
	L8	41,4	36,9	39,2	
	Terminals for external connections .....				P
	The temperature rise does not exceed the value measured during the temperature rise test (sub-clause 9.8) by more than 15 K				P
	Test current 1,45 I <sub>N</sub> = 91,35 A	91,4A			P
	- Tripping within	[s]	[s]	[s]	P
	- 1h (≤ 63 A)	59,6s	1min02s	1min07s	P
	- 2h (> 63 A)				N/A

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	<b>TESTS „B“ 3 samples B63; 1POLE</b>	<b>B<sub>1</sub></b>	<b>B<sub>2</sub></b>	<b>B<sub>3</sub></b>	
	Temperature rise does not exceed the limiting values stated in table 6:	sect. ___16___ mm <sup>2</sup>			P
9.8.2	Test current: I <sub>N</sub> = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	I <sub>N</sub> = _63_ A			P
	Ambient air temperature.....:	T <sub>amb</sub> = _23,3_ °C			P
	Parts ..... Temperature rise [K]	[K]	[K]	[K]	P
	L1	35,6	39,6	38,5	P
	L2	37,4	39,2	34,3	
	Terminals for external connections .....60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles .....40 K	7,5	7,7	7,2	P
	External metallic parts of operating means ...25 K				P
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	29,1	33,5	30,8	P
9.8.5	Measurement of power losses	B <sub>1</sub>	B <sub>2</sub>	B <sub>3</sub>	P
	Power loss do not exceed the values stated in table 8				P
	Test current: I <sub>N</sub> =63 A (reach the steady state value)				P
	Loaded one pole after the other				P
	Max. power loss : ___13_ W	W	W	W	P
	L1	9,01	7,94	8,13	P
	L2	-	-	-	
	L3	-	-	-	
	L4(N)	-	-	-	
	<b>TESTS „B“ 3 samples B63; 4POLE</b>	<b>B<sub>1</sub></b>	<b>B<sub>2</sub></b>	<b>B<sub>3</sub></b>	
	Temperature rise does not exceed the limiting values stated in table 6:	sect. ___16___ mm <sup>2</sup>			P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.8.2	Test current: $I_N$ (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	$I_N = 63$ A			P
	Ambient air temperature .....	Tamb= 23,3 °C			P
	Parts ..... Temperature rise [K]	[K]	[K]	[K]	P
	L1	51,4	40,4	47,5	P
	L2	43,1	41,8	42,5	
	L3	44,8	42,9	46,3	
	L4	49,6	44,9	45,8	
	L5	38,7	47,2	41,5	
	L6	54,0	49,9	49,2	
	L7	42,8	40,4	43,7	
	L8	47,0	39,2	41,1	
	Terminals for external connections .....60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles .....40 K	16,5	12,3	14,8	P
	External metallic parts of operating means ...25 K	-	-	-	N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface .....60 K	33,2	25,6	29,6	P
9.8.5	Measurement of power losses	B <sub>1</sub>	B <sub>2</sub>	B <sub>3</sub>	P
	Power loss do not exceed the values stated in table 8				P
	Test current: $I_N = 63$ A (reach the steady state value)				P
	Loaded one pole after the other				P
	Max. power loss : 13 W	W	W	W	P
	L1	5,71	7,43	7,81	P
	L2	6,87	8,57	6,55	
	L3	6,62	6,74	8,76	

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
		L4(N)	8,92	6,87	7,62
	<b>TESTS „C<sub>1</sub>“ 3 +3 samples D63, 1POLE</b>				<b>P</b>
<b>8.7</b>	<b>Test „C<sub>1</sub>“ Mechanical and electrical endurance</b>	<b>C<sub>1-1</sub></b>	<b>C<sub>1-2</sub></b>	<b>C<sub>1-3</sub></b>	<b>P</b>
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				P
9.11.1	General test conditions				P
	Test: Test Voltage <u>240</u> V (rated voltage) Test Current <u>63</u> A (rated current) Power factor ____ (0,85-0,9) Par. resistor _____ (Ω) Cross sect. area 16mm <sup>2</sup>	Obtained 244 V 63,2 A 0,86			P
9.11.2	Test procedure				P
	The circuit-breaker is submitted to 4000 operating cycles with rated current.				P
	- I <sub>N</sub> ≤ 32 A: 2 s on - 13 s off				N/A
	- I <sub>N</sub> > 32 A: 2 s on - 28 s off	I <sub>n</sub> = 63 A			P
	During the test the circuit-breaker shall be operated as in normal use.				P
9.11.3	Conditions of the circuit breaker after the tests.				P
	Following the test 9.11.2 the sample shall not show:				P
	- undue wear				P
	- discrepancy between the position of the moving contacts and corresponding position of the Indicating device				P
	- damage to the enclosure permitting access to live parts by test finger (see 9.6)				P
	- loosening of electrical or mechanical connections				P
	- seepage of sealing compound				P
	Moreover test current .....2,55 I <sub>N</sub> ___A	161,0A			N/A
	Opening time not less 1 s or more than	[s]	[s]	[s]	P
	- 60 s ( ≤ 32 A)				N/A
	- 120 s ( > 32 A)	43,1s	27,9s	31,2s	P
	Dielectric strength reduced to 1500 V	1500 V; 1 min; 100 mA			P
<b>9.12.11.2</b>	<b>Test at reduced short-circuit currents</b>				<b>P</b>
9.12.11.2.1	Test on all circuit-breakers				P



IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.12.11.2.1	Test at reduced short-circuit currents: Fig. 3				P
	Test current:	Obtained			--
	- 500 A or 10 In	I test= <u>638</u> A			--
	Test voltage 1,05 Un	Un = <u>255</u> V			--
	Power factor 0,93-0,98	<u>0,94</u>			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,80 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = <u>50</u> mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ mm			N/A
	I <sub>Peak</sub> (A) max. value	854	853	852	--
	Sequence: 6 x "O" and 3 x "CO"	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	1,13	0,67	0,71	P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12	Verification of the circuit-breaker after short-circuit tests				P
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times Un.= <u>264</u> V. The circuit – breaker is in the open position	<b>C<sub>1-1</sub></b> [mA]	<b>C<sub>1-2</sub></b> [mA]	<b>C<sub>1-3</sub></b> [mA]	P
	The leakage current shall not exceed 2 mA L1	< 0,01	< 0,01	< 0,01	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
<b>9.12.11.2.2</b>	<b>Test „C<sub>2</sub>“ Short-circuit test on circuit-breakers for use in IT systems (3 sample)</b>				P
	Test current:				P
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2 ) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	1,54kA 0,96			P
	Test voltage 1,05 Un	437V			P
	Power factor 0,93-0,98	0,96			P
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = <u>50 mm</u>			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____x_____x_____mm			N/A
	I <sub>Peak</sub> (A) max. value	1,99 kA	2,00kA	2,01 kA	--
	Sequence: "0" + "CO" on each protected pole	[kA2s]	[kA2s]	[kA2s]	--
	Shifted point 30 ° on the other protected pole	<b>C<sub>2-1</sub></b>	<b>C<sub>2-2</sub></b>	<b>C<sub>2-3</sub></b>	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 L2 L3 L4	14,8 13,1	13,6	P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
<b>9.12.12.1</b>	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.6.3, each pole is supplied at a voltage 1,1 times Un.=457V. The circuit – breaker is in the open position	<b>C<sub>2-1</sub></b> [mA]	<b>C<sub>2-2</sub></b> [mA]	<b>C<sub>2-3</sub></b> [mA]	P
	The leakage current shall not exceed 2 mA L1	< 0,1	< 0,1	< 0,1	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:	1500 V, 1 min, 100 mA			P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test voltage 1500 V (see 8.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A
	<b>TESTS „C<sub>2</sub>“ 2 samples D63, 2POLE</b>				<b>P</b>
<b>9.12.11.2.2</b>	<b>Test „C<sub>2</sub>“ Short-circuit test on circuit-breakers for use in IT systems (3 sample)</b>				<b>P</b>
	Test current:				P
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2 ) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	1,54kA 0,96			P
	Test voltage 1,05 Un	437V			P
	Power factor 0,93-0,98	0,96			P
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = <u>50 mm</u>			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			N/A
	I <sub>Peak</sub> (A) max. value	2,00 kA	2,01kA	1,96 kA	--
	Sequence: "0" + "CO" on each protected pole	[kA2s]	[kA2s]	[kA2s]	--
	Shifted point 30 ° on the other protected pole	<b>C<sub>2-1</sub></b>	<b>C<sub>2-2</sub></b>	<b>C<sub>2-3</sub></b>	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 16,8	L2 15,5	L3 13,9	L4 P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
<b>9.12.12.1</b>	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				<b>P</b>

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	a) leakage current across open contacts, according to 9.7.6.3, each pole is supplied at a voltage 1,1 times $U_n=457V$ . The circuit – breaker is in the open position	<b>C<sub>2-1</sub></b> [mA]	<b>C<sub>2-2</sub></b> [mA]	<b>C<sub>2-3</sub></b> [mA]	P
	The leakage current shall not exceed 2 mA L1	< 0,01	< 0,01	< 0,01	P
	L2	< 0,01	< 0,01	< 0,01	P
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:	1500 V, 1 min, 100 mA			P
	Test voltage 1500 V (see 8.7.2)				P
	a)				P
	b)				P
	c)				P
	d)				N/A
	e) 2000 V				N/A

TESTS „C <sub>1</sub> “ 3 +3 samples D63, 4POLE					P
<b>8.7</b>	<b>Test „C<sub>1</sub>“ Mechanical and electrical endurance</b>	<b>C<sub>1-1</sub></b>	<b>C<sub>1-2</sub></b>	<b>C<sub>1-3</sub></b>	P
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				P
9.11.1	General test conditions				P
	Test: Test Voltage <u>415</u> V (rated voltage) Test Current <u>63</u> A (rated current) Power factor <u>    </u> (0,85-0,9) Par. resistor <u>          </u> (Ω) Cross sect. area 16mm <sup>2</sup>	Obtained 418 V 64,0 A 0,87			P
9.11.2	Test procedure				P
	The circuit-breaker is submitted to 4000 operating cycles with rated current.				P
	- $I_N \leq 32$ A: 2 s on - 13 s off				N/A
	- $I_N > 32$ A: 2 s on - 28 s off	$I_N = 63$ A			P
	During the test the circuit-breaker shall be operated as in normal use.				P
9.11.3	Conditions of the circuit breaker after the tests.				P
	Following the test 9.11.2 the sample shall not show:				P
	- undue wear				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- discrepancy between the position of the moving contacts and corresponding position of the Indicating device				P
	- damage to the enclosure permitting access to live parts by test finger (see 9.6)				P
	- loosening of electrical or mechanical connections				P
	- seepage of sealing compound				P
	Moreover test current .....2,55 I <sub>N</sub> ___A	161A			N/A
	Opening time not less 1 s or more than	[s]	[s]	[s]	P
	- 60 s ( ≤ 32 A)				N/A
	- 120 s ( > 32 A)	39,7s	42,1s	51,2s	P
	Dielectric strength reduced to 1500 V	1500 V; 1 min; 100 mA			P
<b>9.12.11.2</b>	<b>Test at reduced short-circuit currents</b>				P
9.12.11.2.1	Test on all circuit-breakers				P
9.12.11.2.1	Test at reduced short-circuit currents: Fig. 3				P
	Test current:	Obtained			--
	- 500 A or 10 I <sub>N</sub>	I test= <u>638</u> A			--
	Test voltage 1,05 U <sub>n</sub>	U <sub>n</sub> = <u>255</u> V			--
	Power factor 0,93-0,98	<u>0,94</u>			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = <u>35</u> mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			N/A
	I <sub>Peak</sub> (A) max. value	869A	868A	868A	--
	Sequence: 6 x "O" and 3 x "CO"	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	1,12	1,23	0,92	P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12	Verification of the circuit-breaker after short-circuit tests				P
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = \underline{457}$ V. The circuit – breaker is in the open position	<b>C<sub>1-1</sub></b> [mA]	<b>C<sub>1-2</sub></b> [mA]	<b>C<sub>1-3</sub></b> [mA]	P
	The leakage current shall not exceed 2 mA	L1 < 0,01	< 0,01	< 0,01	P
		L2 < 0,01	< 0,01	< 0,01	P
		L3 < 0,01	< 0,01	< 0,01	P
		L4(N) < 0,01	< 0,01	< 0,01	P
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A
<b>9.12.11.2.2</b>	<b>Test „C<sub>2</sub>“ Short-circuit test on circuit-breakers for use in IT systems (3 sample)</b>				P
	Test current:				P
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2 ) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	1,52kA 0,96			P
	Test voltage 1,05 $U_n$	422V			P
	Power factor 0,93-0,98	0,97			P
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = <u>35 mm</u>			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____x_____x_____mm			N/A
	$I_{Peak}$ (A) max. value	2,02 kA	2,00kA	1,97 kA	--
	Sequence: "0" + "CO" on each protected pole	[kA2s]	[kA2s]	[kA2s]	--
	Shifted point 30 ° on the other protected pole	<b>C<sub>2-1</sub></b>	<b>C<sub>2-2</sub></b>	<b>C<sub>2-3</sub></b>	--
	Max. $I^2t \leq$ _____kA <sup>2</sup> s	L1 17,0	L2 16,4	L3 16,6	P
		L4			
	- No permanent arcing				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
<b>9.12.12.1</b>	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.6.3, each pole is supplied at a voltage 1,1 times $U_n=457V$ . The circuit – breaker is in the open position	<b>C<sub>2-1</sub></b> [mA]	<b>C<sub>2-2</sub></b> [mA]	<b>C<sub>2-3</sub></b> [mA]	P
	The leakage current shall not exceed 2 mA L1	< 0,1	< 0,1	< 0,1	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:	1500 V, 1 min, 100 mA			P
	Test voltage 1500 V (see 8.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D63; 1POLE</b>	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-1</sub> D<sub>0-2</sub> D<sub>0-3</sub></b>	P
	I <sub>N</sub> (A)	<u>63</u> A	--
	Sect. (mm <sup>2</sup> )	<u>16</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>71,2</u> A	P
	- 1 h (I <sub>N</sub> ≤ 63 A)		P
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		P
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>91,4</u> A	P
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	1min25s 27,0s 1min02s	P
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	<u>161</u> A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	23,8s 25,4s 26,8s	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	1	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___ 630 ___A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 1260 ___A	N/A
	Tripping less than 0,1 s	5,28ms 6,15ms 5,57ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	161A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	26,8s 25,9s 27,4s	P
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A			N/A
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)				N/A
	- 2h ( $>$ 63 A)				N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A			N/A
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)				N/A
	- 2h ( $>$ 63 A)				N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics				P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____-5_____°C			P
	Test current 1,13 I <sub>N</sub> (A)	____71,4____A			P
	- Passed for 1h				P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	____120____A			P
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)	14,9s	10,8s	15,2s	P
	- 2h ( $>$ 63 A)				N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = ____40_____°C			N/A
	Test current I <sub>N</sub> (A)	63			P
	No tripping within				--
	- 1h ( $\leq$ 63 A)				P
	- 2h ( $>$ 63 A)				N/A
	Tests „D1“	D1-1	D1-2	D1-3	P
<b>8.9</b>	<b>Resistance to mechanical shock and impact</b>				P
	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				P
9.13.1	Mechanical shock				P
	- 50 falls on two sides of vertical board C				P
	- Vertical board turned 90°				P
	- 50 falls on two sides of vertical board C				P
	During the test the circuit-breakers shall not open				P

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.13.2	Mechanical impact				P	
9.13.2.2	All types:				P	
	- Impact test: 10 blows-height 10 cm, no damage				P	
9.13.2.3	Screw-in types:				N/A	
	- Torque 2,5 Nm for 1 min, no damage				N/A	
9.13.2.4	CB intended to be mounted on a rail				P	
	- downward vertical 50 N for 1 min				P	
	- upward vertical 50 N for 1 min, no damage				P	
9.13.2.5	Plug-in types				N/A	
	The circuit-breaker are mounted in their normal position, complete with plug-in base but without cables and any cover plate				N/A	
	A force of 20 N applied for 1min to the circuit-breaker (see fig 16).				N/A	
	During this test the circuit-breaker part shall not become loose from the base and shall not show damage impairing further use.				N/A	
<b>9.12.11.3</b>	<b>Test at 1500 A:</b>				P	
	Prospective current of 1500 A - power factor 0,93 to 0,98				P	
	Prospective current obtained (A)	1,55 kA			--	
	Power factor	0,97			--	
	Test voltage 1,05 Un	258 V			--	
	Test circuit: figure	3/5			--	
	T (min)	3 min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			--	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			--	
	Sequence	6 O – 2 CO - O			--	
	$I_{Peak}$ (A) max. value	1,97kA	1,96kA	2,03kA	--	
	$I^2t \leq$ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--	
	Max. $I^2t \leq$ _____ kA <sup>2</sup> s	L1 L2 L3 L4(N)	11,7 _____ _____ _____ _____	12,7 _____ _____ _____ _____	12,2 _____ _____ _____ _____	P
	- No permanent arcing				P	

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 264 \text{ V}$ . The circuit – breaker is in the open position	<b>D<sub>1-1</sub></b> [mA]	<b>D<sub>1-2</sub></b> [mA]	<b>D<sub>1-3</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2				N/A
		L3				N/A
		L4(N)				N/A
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.2)				P	
	a)				P	
	b)				N/A	
	c)				P	
	d)				N/A	
	e) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 $I_N$ )		<u>60,8</u> A		P	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 $I_N$ ) within 5s		<u>101</u> A		P	
		<b>D<sub>1-1</sub></b> [min]	<b>D<sub>1-2</sub></b> [min]	<b>D<sub>1-3</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	3min17s	4min32s	2min03s	P	

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D63; 4POLE</b>	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-1</sub> D<sub>0-2</sub> D<sub>0-3</sub></b>	P
	I <sub>N</sub> (A)	<u>63</u> A	--
	Sect. (mm <sup>2</sup> )	<u>16</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>71,2</u> A	P
	- 1 h (I <sub>N</sub> ≤ 63 A)		P
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		P
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>91,4</u> A	P
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	1min03s 49,8s 30,6s	P
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	<u>161</u> A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	26,8s 28,0s 28,1s	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___ 630 ___A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 1260 ___A	N/A
	Tripping less than 0,1 s	7,11ms 6,19ms 6,58ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	161A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	27,2s 28,3s 28,5s	P
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A			N/A
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)				N/A
	- 2h ( $>$ 63 A)				N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	___111___A			P
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)	2min03s 1min58s 2min04s			P
	- 2h ( $>$ 63 A)				N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics				P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = ___-5___°C			P
	Test current 1,13 I <sub>N</sub> (A)	___71,2___A			P
	- Passed for 1h				P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	___120___A			P
	Tripping within	[min]	[min]	[min]	--
	- 1h ( $\leq$ 63 A)	11,2s	8,95s	9,10s	P
	- 2h ( $>$ 63 A)				N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = ___40___°C			N/A
	Test current I <sub>N</sub> (A)	63			P
	No tripping within				--
	- 1h ( $\leq$ 63 A)				P
	- 2h ( $>$ 63 A)				N/A
	Tests „D1“	D1-1	D1-2	D1-3	P
<b>8.9</b>	<b>Resistance to mechanical shock and impact</b>				P
	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				P
9.13.1	Mechanical shock				P
	- 50 falls on two sides of vertical board C				P
	- Vertical board turned 90°				P
	- 50 falls on two sides of vertical board C				P
	During the test the circuit-breakers shall not open				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.13.2	Mechanical impact				P
9.13.2.2	All types:				P
	- Impact test: 10 blows-height 10 cm, no damage				P
9.13.2.3	Screw-in types:				N/A
	- Torque 2,5 Nm for 1 min, no damage				N/A
9.13.2.4	CB intended to be mounted on a rail				P
	- downward vertical 50 N for 1 min				P
	- upward vertical 50 N for 1 min, no damage				P
9.13.2.5	Plug-in types				N/A
	The circuit-breaker are mounted in their normal position, complete with plug-in base but without cables and any cover plate				N/A
	A force of 20 N applied for 1min to the circuit-breaker (see fig 16).				N/A
	During this test the circuit-breaker part shall not become loose from the base and shall not show damage impairing further use.				N/A
<b>9.12.11.3</b>	<b>Test at 1500 A:</b>				P
	Prospective current of 1500 A - power factor 0,93 to 0,98				P
	Prospective current obtained (A)	1,52 kA			--
	Power factor	0,97			--
	Test voltage 1,05 Un	439 V			--
	Test circuit: figure	3/5			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			--
	Sequence	6 O – 2 CO - O			--
	$I_{Peak}$ (A) max. value	1,79kA	1,85kA	1,83kA	--
	$I^2t \leq$ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. $I^2t \leq$ _____ kA <sup>2</sup> s	L1 11,2	L2 10,2	L3 11,3	P
		L4(N) _____	_____	_____	
	- No permanent arcing				P



IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457 \text{ V}$ . The circuit – breaker is in the open position	<b>D<sub>1-1</sub></b> [mA]	<b>D<sub>1-2</sub></b> [mA]	<b>D<sub>1-3</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	<0,01	<0,01	<0,01	P
		L3	<0,01	<0,01	<0,01	P
		L4(N)	<0,01	<0,01	<0,01	P
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.2)				P	
	a)				P	
	b)				P	
	c)				P	
	d)				N/A	
	e) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 $I_N$ )		<u>60,8</u> A		P	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 $I_N$ ) within 5s		<u>101</u> A		P	
		<b>D<sub>1-1</sub></b> [min]	<b>D<sub>1-2</sub></b> [min]	<b>D<sub>1-3</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	4min17s	2min28s	3min14s	P	

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D50; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-1</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>50</u> A	--
	Sect. (mm <sup>2</sup> )	<u>10</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		<b>P</b>
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		<b>P</b>
9.10.2	Test of time-current characteristic		<b>P</b>
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>56,6</u> A	<b>P</b>
	- 1 h (I <sub>N</sub> ≤ 63 A)		<b>P</b>
	- 2 h (I <sub>N</sub> > 63 A)		<b>N/A</b>
	No tripping		<b>P</b>
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>72,6</u> A	<b>P</b>
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	8min19s	<b>P</b>
	- 2h (> 63 A)		<b>N/A</b>
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	<u>128</u> A	<b>P</b>
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		<b>N/A</b>
	- 120 s (> 32 A)	18,1s	<b>P</b>
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	1	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___ 500 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 1000 ___ A	N/A
	Tripping less than 0,1 s	7,52ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	128A	P
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	18,7	P
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = ___-5___ °C	P
	Test current 1,13 I <sub>N</sub> (A)	___56,8___ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	___95,2___ A	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)	24,9s	P
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = ___40___ °C	P
	Test current I <sub>N</sub> (A)	50A	P
	No tripping within		--
	- 1h ( $\leq$ 63 A)		P
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D40; 1POLE</b>	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-2</sub></b>	P
	I <sub>N</sub> (A)	<u>40</u> A	--
	Sect. (mm <sup>2</sup> )	<u>10</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>45,2</u> A	P
	- 1 h (I <sub>N</sub> ≤ 63 A)		P
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		P
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>58,0</u> A	P
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	1min46s	P
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	<u>102</u> A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	9,40s	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold		N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	__400__A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	__800__A	N/A
	Tripping less than 0,1 s	8,12ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	__102__A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	10,9s	P
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	-5°C	P
	Test current 1,13 I <sub>N</sub> (A)		P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	76,0s	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)	10,1s	P
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	40°C	P
	Test current I <sub>N</sub> (A)	40	P
	No tripping within		--
	- 1h ( $\leq$ 63 A)		P
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D32; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-3</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>32</u> A	--
	Sect. (mm <sup>2</sup> )	<u>6</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		<b>P</b>
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		<b>P</b>
9.10.2	Test of time-current characteristic		<b>P</b>
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>36,2</u> A	<b>P</b>
	- 1 h (I <sub>N</sub> ≤ 63 A)		<b>P</b>
	- 2 h (I <sub>N</sub> > 63 A)		<b>N/A</b>
	No tripping		<b>P</b>
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>46,4</u> A	<b>P</b>
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	3min19s	<b>P</b>
	- 2h (> 63 A)		<b>N/A</b>
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	<u>81,6</u> A	<b>P</b>
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		<b>N/A</b>
	- 120 s (> 32 A)	21,8s	<b>P</b>
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___ 320 ___ A	P
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	3,25s	P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 641 ___ A	N/A
	Tripping less than 0,1 s	6,59ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	81,6A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	23,2s	P
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = ____ -5 ____ °C	P
	Test current 1,13 I <sub>N</sub> (A)	____ 36,2 ____ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	____ 60,8 ____ A	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)	36,2s	P
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = ____ 40 ____ °C	P
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		P
	- 2h ( $>$ 63 A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>D25; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-4</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>25</u> A	--
	Sect. (mm <sup>2</sup> )	<u>4</u> mm <sup>2</sup>	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current $1,13 I_N$ (A) starting from cold for:	<u>28,3A</u>	P
	- 1 h ( $I_N \leq 63$ A)		P
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		P
	Then steadily increased within 5 s to $1,45 I_N$ (A)	<u>36,3A</u>	P
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	1min59s	P
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:	63,8A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	15,1s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	1	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___250___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___500___ A	N/A
	Tripping less than 0,1 s	6,52ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	63,8A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	14,5s	P
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		P
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = <u>      </u> -5 <u>      </u> °C	P
	Test current 1,13 I <sub>N</sub> (A)	<u>  28,3  </u> A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	<u>  47,5  </u> A	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	9,20s	P
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = <u>  40  </u> °C	N/A
	Test current I <sub>N</sub> (A)	25A	P
	No tripping within		--
	- 1h ( $\leq 63$ A)		P
	- 2h ( $> 63$ A)		N/A

	TESTS „D“ 1 sample	D20; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-5</sub></b>	P
	I <sub>N</sub> (A)	<u>20</u> A	--
	Sect. (mm <sup>2</sup> )	<u>4</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>22,6</u> A	P
	- 1 h (I <sub>N</sub> $\leq 63$ A)		P
	- 2 h (I <sub>N</sub> $> 63$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	No tripping		P
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	29,0A	P
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	9min40s	P
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	51,0A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	15,7s	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current 3I <sub>N</sub> (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 5 I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current 5I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 10 I <sub>N</sub> (A), starting from cold	_____ A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current 10I <sub>N</sub> (A), starting from cold	___ 200 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current 20 I <sub>N</sub> (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 400 ___ A	P
	Tripping less than 0,1 s	7,45ms	P
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	51,0A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	16,4s	P
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of (35 $\pm$ 2) K below the ambient air reference temperature	T = ___ -5 ___ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	___ 22,6 ___ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	<u>38,0</u> A	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	16,2s	P
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = <u>40</u> °C	N/A
	Test current $I_N$ (A)	20A	P
	No tripping within		--
	- 1h ( $\leq 63$ A)		P
	- 2h ( $> 63$ A)		N/A

	TESTS „D“ 1 sample	D16; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D0“</b>	<b>D<sub>0-6</sub></b>	P
	$I_N$ (A)	<u>16</u> A	--
	Sect. (mm <sup>2</sup> )	<u>2,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current $1,13 I_N$ (A) starting from cold for:	<u>18,1</u> A	P
	- 1 h ( $I_N \leq 63$ A)		P
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		P
	Then steadily increased within 5 s to $1,45 I_N$ (A)	<u>23,2</u> A	P
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	1min12s	P
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:	40,8A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	12,4s	P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___160___A	P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		P
	Test current 20 I <sub>N</sub> (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ 320 _____ A	N/A
	Tripping less than 0,1 s	8,52ms	P
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	40,8A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)	15,1s	P
	- 120 s (> 32 A)		N
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		P
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = _____ -5 _____ °C	P
	Test current 1,13 I <sub>N</sub> (A)	___ 18,1 _____ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____ 30,4 _____ A	P
	Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	2,60s	P
	- 2h (> 63 A)		N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = _____ 40 _____ °C	N/A
	Test current I <sub>N</sub> (A)	16A	P
	No tripping within		--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 1h ( $\leq 63$ A)		P
	- 2h ( $> 63$ A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>D10; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D0“</b>	<b>D0-7</b>	<b>P</b>
	$I_N$ (A)	<u>10A</u>	--
	Sect. (mm <sup>2</sup> )	<u>1,5mm<sup>2</sup></u>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		P
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		P
9.10.2	Test of time-current characteristic		P
9.10.2.1	Test current 1,13 $I_N$ (A) starting from cold for:	<u>11,3A</u>	P
	- 1 h ( $I_N \leq 63$ A)		P
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		P
	Then steadily increased within 5 s to 1,45 $I_N$ (A)	<u>14,5A</u>	P
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	8min15s	P
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current 2,55 $I_N$ (A) starting from cold for:	25,5A	P
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	13,2s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ ( phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: $> 3$ min		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___100___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___200___ A	P
	Tripping less than 0,1 s	6,95ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	25,5A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	14,0s	P
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = ____ -5 ____ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	__ 11,3 ____ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	__ 19,0 ____ A	P
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)	17,9s	P
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = __ 40 ____ °C	N/A
	Test current I <sub>N</sub> (A)	10,0A	P
	No tripping within		--
	- 1h ( $\leq$ 63 A)		P
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>D6; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-8</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>6</u> A	--
	Sect. (mm <sup>2</sup> )	<u>1</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D	--
9.10.1	General		<b>P</b>
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		<b>P</b>
9.10.2	Test of time-current characteristic		<b>P</b>
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:	<u>6,80</u> A	<b>P</b>
	- 1 h (I <sub>N</sub> ≤ 63 A)		<b>P</b>
	- 2 h (I <sub>N</sub> > 63 A)		<b>N/A</b>
	No tripping		<b>P</b>
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)	<u>8,70</u> A	<b>P</b>
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)	9min04s	<b>P</b>
	- 2h (> 63 A)		<b>N/A</b>
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	15,3A	<b>P</b>
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)	12,9s	<b>P</b>
	- 120 s (> 32 A)		<b>N/A</b>
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current $10I_N$ (A), starting from cold	___ 60 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	___ 120 ___ A	N/A
	Tripping less than 0,1 s	7,54ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	15,3A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	12,3s	P
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = ____ -5 ____ °C	P
	Test current 1,13 I <sub>N</sub> (A)	__6,80__ A	P
	- Passed for 1h		P
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	__11,4__ A	P
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)	17,9s	P
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = __40__ °C	P
	Test current I <sub>N</sub> (A)	6,0A	P
	No tripping within		--
	- 1h ( $\leq 63$ A)		P
	- 2h ( $> 63$ A)		N/A



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>C63; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-13</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>63A</u>	--
	Sect. (mm <sup>2</sup> )	<u>16mm<sup>2</sup></u>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	_____A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	<u>315</u> A	P
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	630	P
	Tripping less than 0,1 s	8,92	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	161A	P
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	28,5s	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	_____A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	-5°C	N/A
	Test current 1,13 I <sub>N</sub> (A)		N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s		N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	40°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

	TESTS „D“ 1 sample	C50; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-14</sub></b>	P
	I <sub>N</sub> (A)	50A	--
	Sect. (mm <sup>2</sup> )	10mm <sup>2</sup>	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current 3I <sub>N</sub> (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 5 I <sub>N</sub> (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___251___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	___500___ A	N/A
	Tripping less than 0,1 s	9,83	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	128	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	21,3s	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____ °C	N/A
	Test current $1,13 I_N$ (A)	_____ A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	_____ A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current $I_N$ (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A

	TESTS „D“ 1 sample	C40; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-15</sub></b>	P
	$I_N$ (A)	<u>40</u> A	--
	Sect. (mm <sup>2</sup> )	<u>10</u> mm <sup>2</sup>	--

	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current $1,13 I_N$ (A) starting from cold for:		N/A
	- 1 h ( $I_N \leq 63$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to $1,45 I_N$ (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: $> 3$ min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___200___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current $10 I_N$ (A), starting from cold	<u>400</u> A	N/A
	Tripping less than 0,1 s	9,56ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	102	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	11,9s	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10 I_N$ (A), starting from cold	<u>        </u> A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	<u>        </u> A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	<u>        </u> A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	<u>        </u> A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = <u>        </u> °C	N/A
	Test current $1,13 I_N$ (A)	<u>        </u> A	N/A
	- Passed for 1h		N/A



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current $I_N$ (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A

	TESTS „D“ 1 sample	C32; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-16</sub></b>	P
	$I_N$ (A)	<u>32</u> A	--
	Sect. (mm <sup>2</sup> )	<u>6</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current $1,13 I_N$ (A) starting from cold for:		N/A
	- 1 h ( $I_N \leq 63$ A)		N/A
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to $1,45 I_N$ (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: $> 3$ min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___ 160 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	___ 320 ___ A	N/A
	Tripping less than 0,1 s	9,14ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	81,6A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	25,9s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current $1,13 I_N$ (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current $I_N$ (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>C25; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-17</sub></b>	<b>P</b>
	$I_N$ (A)	<u>25A</u>	--
	Sect. (mm <sup>2</sup> )	<u>4mm<sup>2</sup></u>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 $I_N$ (A) starting from cold for:		N/A
	- 1 h ( $I_N \leq 63$ A)		N/A
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 $I_N$ (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current 2,55 $I_N$ (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___ 125 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	___ 250 ___ A	N/A
	Tripping less than 0,1 s	9,42ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	63,8A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	18,9s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>C20; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-18</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>20</u> A	--
	Sect. (mm <sup>2</sup> )	<u>2,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current $3I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $5 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current $2,55 I_N$ (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___ 100___A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	___ 201___ A	N/A
	Tripping less than 0,1 s	10,1ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	51,0A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	19,9s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>C16; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-19</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>16</u> A	--
	Sect. (mm <sup>2</sup> )	<u>2,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current 3I <sub>N</sub> (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 5 I <sub>N</sub> (A), starting from cold	_____A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Tripping less than 0,1 s		N/A
*)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq$ 32 A)		N/A
	- 120 s ( $>$ 32 A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current 5I <sub>N</sub> (A), starting from cold	___ 80 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq$ 0,1 s		P
	Test current 10 I <sub>N</sub> (A), starting from cold	___ 161 ___ A	N/A
	Tripping less than 0,1 s	9,82ms	P
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	40,8A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq$ 32 A)	15,9s	P
	- 120 s ( $>$ 32 A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current 10I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq$ 0,1 s		N/A
	Test current 20 I <sub>N</sub> (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq$ 32 A)		N/A
	- 120 s ( $>$ 32 A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>C10; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-20</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>10</u> A	--
	Sect. (mm <sup>2</sup> )	<u>1,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current 3I <sub>N</sub> (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 5 I <sub>N</sub> (A), starting from cold	_____A	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Tripping less than 0,1 s		N/A
*)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current 5I <sub>N</sub> (A), starting from cold	___ 50 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		P
	Test current 10 I <sub>N</sub> (A), starting from cold	___ 100 ___ A	N/A
	Tripping less than 0,1 s	9,53ms	P
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	25,5A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)	17,8s	P
	- 120 s (> 32 A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current 10I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 20 I <sub>N</sub> (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = _____ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____ A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = _____ °C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A

	TESTS „D“ 1 sample	C6; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-21</sub></b>	P
	I <sub>N</sub> (A)	<u>30,1</u> A	--
	Sect. (mm <sup>2</sup> )	<u>1,0</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	The tripping time of the O operation is measured		P
	After each operation the indicating means shall show the open position of the contacts		P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type		N/A
	Test current 3I <sub>N</sub> (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 5 I <sub>N</sub> (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
*)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	A	N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current $5I_N$ (A), starting from cold	___ 30,1 ___ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $10 I_N$ (A), starting from cold	___ 60,1 ___ A	N/A
	Tripping less than 0,1 s	9,17ms	P
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:	15,3A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	14,9s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____ A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____ A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____ A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h (> 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h (> 63 A)		N/A

	TESTS „D“ 1 sample	B63; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-26</sub></b>	P
	I <sub>N</sub> (A)	<u>63,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>16,0</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> $\leq$ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	After each operation the indicating means shall show the open position of the contacts		P
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current 3I <sub>N</sub> (A), starting from cold	___189___ A	--
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		P
	Test current 5 I <sub>N</sub> (A), starting from cold	___315___ A	N/A
	Tripping less than 0,1 s	11,2ms	P
	Test current 2,55 I <sub>N</sub> (A) starting from cold for:	161A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	27,6s	P
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current 5I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	≥ 0,1 s		N/A
	Test current 10 I <sub>N</sub> (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current $1,13 I_N$ (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [min]	--

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current $I_N$ (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	<b>TESTS „D“ 1 sample</b>	<b>B50; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-27</sub></b>	<b>P</b>
	$I_N$ (A)	<u>50,0A</u>	--
	Sect. (mm <sup>2</sup> )	<u>10,0mm<sup>2</sup></u>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 $I_N$ (A) starting from cold for:		N/A
	- 1 h ( $I_N \leq 63$ A)		N/A
	- 2 h ( $I_N > 63$ A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 $I_N$ (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.2.2	Test current 2,55 $I_N$ (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage $U_n$ (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	After each operation the indicating means shall show the open position of the contacts		P
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	___150___ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $5 I_N$ (A), starting from cold	___251___ A	N/A
	Tripping less than 0,1 s	11,5ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	128A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	23,7s	P
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
*see Annex 1 acc. EN60898-1	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current $1,13 I_N$ (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current $I_N$ (A)		N/A
	No tripping within		--
	- 1h ( $\leq 63$ A)		N/A
	- 2h ( $> 63$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TESTS „D“ 1 sample	B40; 1POLE	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-28</sub></b>	P
	I <sub>N</sub> (A)	40,0A	--
	Sect. (mm <sup>2</sup> )	10,0mm <sup>2</sup>	--

	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	After each operation the indicating means shall show the open position of the contacts		P



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	_____ 120 _____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $5 I_N$ (A), starting from cold	_____ 200 _____ A	N/A
	Tripping less than 0,1 s	10,9ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	102A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)	13,8s	P
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B32; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-29</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>32,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>6,0</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	_____96,0_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		P
	Test current $5 I_N$ (A), starting from cold	_____160_____A	N/A
	Tripping less than 0,1 s	12,2ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	81,6A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	23,9s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B25; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-30</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>25,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>4,0</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>
	The tripping time of the O operation is measured		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	___ 60,0 ___ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	11,5s	P
	Test current $5 I_N$ (A), starting from cold	___ 100 ___ A	N/A
	Tripping less than 0,1 s	11,5ms	P
	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	19,7s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B20; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-30</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>20,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>2,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> (phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	_____ 60,0 _____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	11,7s	P
	Test current $5 I_N$ (A), starting from cold	_____ 100 _____ A	N/A
	Tripping less than 0,1 s	11,9ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	51,0A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	22,7s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B16; 1POLE</b>	P
<b>8.6</b>	<b>Automatic operation</b>		P
8.6.1	Standard time-current zone		P
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		P
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-30</sub></b>	P
	I <sub>N</sub> (A)	<u>16,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>2,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		P
9.10.3.1	General test conditions		P
	For the lower values of the test current the test is made once, at any convenient voltage.		P
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		P
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		P
	After each operation the indicating means shall show the open position of the contacts		P

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	____ 48,0 ____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	10,5s	P
	Test current $5 I_N$ (A), starting from cold	____ 80,1 ____ A	N/A
	Tripping less than 0,1 s	11,6ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	40,8A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	17,7s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B10; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-30</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>10,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>1,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	____ 30,0 ____ A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	9,55s	P
	Test current $5 I_N$ (A), starting from cold	____ 50,1 ____ A	N/A
	Tripping less than 0,1 s	12,3ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	25,5A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	30,2s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	____ A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	____ A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A



IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 I <sub>t</sub> (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	Test current 1,2 I <sub>t</sub> (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = _____°C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = _____°C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>TESTS „D“ 1 sample</b>	<b>B6; 1POLE</b>	<b>P</b>
<b>8.6</b>	<b>Automatic operation</b>		<b>P</b>
8.6.1	Standard time-current zone		<b>P</b>
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		<b>P</b>
<b>9.10</b>	<b>Tests „D<sub>0</sub>“</b>	<b>D<sub>0-33</sub></b>	<b>P</b>
	I <sub>N</sub> (A)	<u>6,0</u> A	--
	Sect. (mm <sup>2</sup> )	<u>1,5</u> mm <sup>2</sup>	--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	--
9.10.1	General		N/A
	If the test is made in a test chamber, it shall be made in still air; the volume of the test chamber shall be such as not to affect the test results		N/A
9.10.2	Test of time-current characteristic		N/A
9.10.2.1	Test current 1,13 I <sub>N</sub> (A) starting from cold for:		N/A
	- 1 h (I <sub>N</sub> ≤ 63 A)		N/A
	- 2 h (I <sub>N</sub> > 63 A)		N/A
	No tripping		N/A
	Then steadily increased within 5 s to 1,45 I <sub>N</sub> (A)		N/A
	- Tripping within	[min]   [min]   [mini]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I <sub>N</sub> (A) starting from cold for:		N/A
	opening time not less than 1 s or more than	[s]   [s]   [s]	--
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.3	Test of instantaneous tripping and of correct opening of the contacts		<b>P</b>
9.10.3.1	General test conditions		<b>P</b>
	For the lower values of the test current the test is made once, at any convenient voltage.		<b>P</b>
	For the upper values of the test current the test is made at rated voltage U <sub>n</sub> ( phase to neutral) with a power factor between 0,95 and 1.		<b>P</b>
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min		<b>P</b>
	After each operation the indicating means shall show the open position of the contacts		<b>P</b>

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The tripping time of the O operation is measured		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current $3I_N$ (A), starting from cold	_____18,0_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s	11,7s	P
	Test current $5 I_N$ (A), starting from cold	_____30,1_____A	N/A
	Tripping less than 0,1 s	11,9ms	P
	Test current $2,55 I_N$ (A) starting from cold for:	15,3A	N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)	15,8s	P
	- 120 s ( $> 32$ A)		N/A
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type		N/A
	Test current $5I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10 I_N$ (A), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		N/A
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold	_____A	N/A
	Tripping less than 0,1 s		N/A
9.10.2.2 *)	Test current $2,55 I_N$ (A) starting from cold for:		N/A
<i>*see Annex 1 acc. EN60898-1</i>	opening time not less than 1 s or more than	[s] [s] [s]	--
	- 60 s ( $\leq 32$ A)		N/A
	- 120 s ( $> 32$ A)		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		N/A
	Test current 1,1 It (A), (two pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A	N/A
	Tripping within	[min] [min] [min]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		N/A
	a) Ambient temperature of $(35 \pm 2)$ K below the ambient air reference temperature	T = _____ °C	N/A
	Test current 1,13 I <sub>N</sub> (A)	_____A	N/A
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to 1,9 I <sub>N</sub> (A) within 5s	_____A	N/A
	Tripping within	[min] [min] [mini]	--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A
	b) Ambient temperature of $(10 \pm 2)$ K above the ambient air reference temperature	T = _____ °C	N/A
	Test current I <sub>N</sub> (A)		N/A
	No tripping within		--
	- 1h ( $\leq$ 63 A)		N/A
	- 2h ( $>$ 63 A)		N/A

TESTS „E <sub>1</sub> “ 3 samples D63, 1POLE,					P
9.12.11.4. 2	Test E <sub>1</sub> : Test at service short-circuit capacity	E <sub>1-1</sub>	E <sub>1-2</sub>	E <sub>1-3</sub>	P
	Service short-circuit capacity (I <sub>cs</sub> ) .....	6kA			--
	Test circuit: figure .....	3			--
	Test voltage 1,05 Un	256V			--
	Prospective current .....	6kA			--

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Prospective current obtained .....	6,11 kA			--
	Power factor .....	0,65...0,70			--
	Power factor obtained .....	0,68			--
	Sequence .....	O - O - CO			--
	T (min) .....	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,80 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 50 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: x x mm			--
	I <sub>Peak</sub> (A) max. value .....	4,17kA	5,79kA	5,06kA	--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 45,5	L2 109	L3 67,0	P
		L4(N) ---	---	---	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U <sub>n</sub> . = 264 V. The circuit – breaker is in the open position	E <sub>1-1</sub> [mA]	E <sub>1-2</sub> [mA]	E <sub>1-3</sub> [mA]	--
	The leakage current shall not exceed 2 mA	L1 <0,01	L2 <0,01	L3 <0,01	P
		L4(N) ---	---	---	N/A
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.2)				P
	a)				P

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A
	Test current 0.85x non-tripping current (1,13 I <sub>N</sub> )	60,8 A			--
	- Passed for 1h				P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I <sub>N</sub> ) within 5s	101 A			--
		E <sub>1-1</sub> [min]	E <sub>1-2</sub> [min]	E <sub>1-3</sub> [min]	--
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	2min19s	1min22s	4min07s	P
<b>9.12.11.4.2</b>	<b>Test „E<sub>1</sub>“ (Test at service short-circuit capacity) three phase tests for single circuit-breakers</b>	E <sub>1-4</sub>	E <sub>1-5</sub>	E <sub>1-6</sub>	P
	Service short-circuit capacity (I <sub>cs</sub> ) .....	6 kA			--
	Test circuit: figure .....	3			--
	Test voltage 1,05 Un	438 V			--
	Prospective current .....	6,0 kA			--
	Prospective current obtained .....	6,24 kA			--
	Power factor .....	0,65-0,70			--
	Power factor obtained .....	0,67			--
	Sequence .....	3/5			--
	T (min) .....	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = 50 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: x x mm			P
	I <sub>Peak</sub> (A) max. value .....	5,43 kA			P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = \underline{\underline{264}}$ V. The circuit – breaker is in the open position	<b>E<sub>1-4</sub></b> [mA]	<b>E<sub>1-5</sub></b> [mA]	<b>E<sub>1-6</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.3)				P	
	a)				P	
	b)				N/A	
	c)				P	
	d) 2000 V				P	
	Test current 0.85x non-tripping current (1,13 $I_N$ )		<u>60,8</u> A		P	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 $I_N$ ) within 5s		<u>101</u> A		P	
		<b>E<sub>1-4</sub></b> [min]	<b>E<sub>1-5</sub></b> [min]	<b>E<sub>1-6</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	1min23s	3min27s	2min50s	P	
	<b>TESTS „E<sub>1</sub>“ 3 samples D6, 1POLE,</b>				P	
<b>9.12.11.4.2</b>	<b>Test E<sub>1</sub>: Test at service short-circuit capacity</b>	<b>E<sub>1-1</sub></b>	<b>E<sub>1-2</sub></b>	<b>E<sub>1-3</sub></b>	<b>P</b>	
	Service short-circuit capacity (Ics) .....	<u>6kA</u>			--	
	Test circuit: figure .....	<u>3</u>			--	
	Test voltage 1,05 $U_n$	<u>256V</u>			--	
	Prospective current .....	<u>6kA</u>			--	
	Prospective current obtained .....	<u>6,06 kA</u>			--	
	Power factor .....	<u>0,65...0,70</u>			--	
	Power factor obtained .....	<u>0,68</u>			--	
	Sequence .....	<u>0 – 0 – CO</u>			--	

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	T (min) .....	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 50 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: x x mm			--
	I <sub>Peak</sub> (A) max. value .....	2,95kA	2,96kA	3,61kA	--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 15,1	L2 19,7	L3 30,7	P
		L3 ---	L4(N) ---	---	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U <sub>n</sub> . = 264 V. The circuit – breaker is in the open position	E <sub>1-1</sub> [mA]	E <sub>1-2</sub> [mA]	E <sub>1-3</sub> [mA]	--
	The leakage current shall not exceed 2 mA	L1 <0,01	L2 <0,01	L3 <0,01	P
		L4(N) <0,01			N/A
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A
	Test current 0.85x non-tripping current (1,13 I <sub>N</sub> )	1,45 A			--
	- Passed for 1h				P



IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I <sub>N</sub> ) within 5s	2,40 A			--	
		E <sub>1-1</sub> [min]	E <sub>1-2</sub> [min]	E <sub>1-3</sub> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	3min29s	4min07s	3min21s	P	
<b>9.12.11.4.2</b>	<b>Test „E<sub>1</sub>“ (Test at service short-circuit capacity) three phase tests for single circuit-breakers</b>	E <sub>1-4</sub>	E <sub>1-5</sub>	E <sub>1-6</sub>	P	
	Service short-circuit capacity (Ics) .....	6 kA			--	
	Test circuit: figure .....	3			--	
	Test voltage 1,05 Un	438 V			--	
	Prospective current .....	6 kA			--	
	Prospective current obtained .....	6,24 kA			--	
	Power factor .....	0,65-0,70			--	
	Power factor obtained .....	0,67			--	
	Sequence .....	3/5			--	
	T (min) .....	3 min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = 50 mm			--	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: x x mm			P	
	I <sub>Peak</sub> (A) max. value .....	3,70 kA			P	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times Un.= 264 V. The circuit – breaker is in the open position	E <sub>1-4</sub> [mA]	E <sub>1-5</sub> [mA]	E <sub>1-6</sub> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	-	-	-	N/A

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.3)				P
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				P
	Test current 0.85x non-tripping current (1,13 I <sub>N</sub> )	___ 5,80 ___ A			P
	- Passed for 1h				P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I <sub>N</sub> ) within 5s	___ 9,60 ___ A			P
		<b>E<sub>1-4</sub></b> [min]	<b>E<sub>1-5</sub></b> [min]	<b>E<sub>1-6</sub></b> [min]	--
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	2min11s	3min33s	4min17s	P

TESTS „E <sub>1</sub> “ 3 samples D63, 2POLE,					P
<b>9.12.11.4.2</b>	<b>Test E<sub>1</sub>: Test at service short-circuit capacity</b>	<b>E<sub>1-1</sub></b>	<b>E<sub>1-2</sub></b>	<b>E<sub>1-3</sub></b>	<b>P</b>
	Service short-circuit capacity (I <sub>cs</sub> ) .....	6kA			--
	Test circuit: figure .....	3			--
	Test voltage 1,05 Un	437V			--
	Prospective current .....	6,0kA			--
	Prospective current obtained .....	6,15 kA			--
	Power factor .....	0,65...0,70			--
	Power factor obtained .....	0,66			--
	Sequence .....	O – O – CO			--
	T (min) .....	___ 3 ___ min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = ___ 50 ___ mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ mm			--
	I <sub>Peak</sub> (A) max. value .....	5,93kA	5,05kA	4,75kA	--

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	$I^2t \leq \text{_____ kA}^2\text{s}$	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--	
	Max. $I^2t \leq \text{_____ kA}^2\text{s}$	L1 L2 L3 L4(N)	172 _____ _____ _____ _____	<u>119</u> _____ _____ _____ _____	<u>85,7</u> _____ _____ _____ _____	P
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = \text{__457__ V}$ . The circuit – breaker is in the open position	<b>E<sub>1-1</sub></b> [mA]	<b>E<sub>1-2</sub></b> [mA]	<b>E<sub>1-3</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	<0,01	<0,01	<0,01	P
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.2)				P	
	a)				P	
	b)				N/A	
	c)				P	
	d)				N/A	
	e) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 $I_N$ )	<u>60,8</u> A			--	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 $I_N$ ) within 5s	<u>101</u> A			--	
		<b>E<sub>1-1</sub></b> [min]	<b>E<sub>1-2</sub></b> [min]	<b>E<sub>1-3</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	<u>1min19s</u>	<u>4min27s</u>	<u>5min02s</u>	P	

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

TESTS „E1“ 3 samples D6, 2POLE,					P
9.12.11.4.2	Test E <sub>1</sub> : Test at service short-circuit capacity	E <sub>1-1</sub>	E <sub>1-2</sub>	E <sub>1-3</sub>	P
	Service short-circuit capacity (I <sub>cs</sub> ) .....	6kA			--
	Test circuit: figure .....	3			--
	Test voltage 1,05 Un	437V			--
	Prospective current .....	6,0kA			--
	Prospective current obtained .....	6,15 kA			--
	Power factor .....	0,65...0,70			--
	Power factor obtained .....	0,66			--
	Sequence .....	O – O – CO			--
	T (min) .....	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 50 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: x x mm			--
	I <sub>Peak</sub> (A) max. value .....	3,03kA	3,78kA	2,15kA	--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 32,3	L2 62,8	L3 18,0	P
		L4(N)	—	—	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times Un.= <u>457</u> V. The circuit – breaker is in the open position	<b>E<sub>1-1</sub></b> [mA]	<b>E<sub>1-2</sub></b> [mA]	<b>E<sub>1-3</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	<0,01	<0,01	<0,01	P
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.2)				P	
	a)				P	
	b)				N/A	
	c)				P	
	d)				N/A	
	e) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 I <sub>N</sub> )	<u>5,80</u> A			--	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I <sub>N</sub> ) within 5s	<u>9,60</u> A			--	
		<b>E<sub>1-1</sub></b> [min]	<b>E<sub>1-2</sub></b> [min]	<b>E<sub>1-3</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	<u>2min19s</u>	<u>4min21s</u>	<u>3min11s</u>	P	
	<b>TESTS „E<sub>1</sub>“ 3 samples D63, 4POLE</b>				<b>P</b>	
<b>9.12.11.4.2</b>	<b>Test E<sub>1</sub>: Test at service short-circuit capacity</b>	<b>E<sub>1-1</sub></b>	<b>E<sub>1-2</sub></b>	<b>E<sub>1-3</sub></b>	<b>P</b>	
	Service short-circuit capacity (Ics) .....	<u>6kA</u>			--	
	Test circuit: figure .....	<u>3</u>			--	
	Test voltage 1,05 Un	<u>438V</u>			--	
	Prospective current .....	<u>6kA</u>			--	
	Prospective current obtained .....	<u>6,24 kA</u>			--	
	Power factor .....	<u>0,65...0,70</u>			--	
	Power factor obtained .....	<u>0,67</u>			--	
	Sequence .....	<u>0 – 0 – CO</u>			--	
	T (min) .....	<u>3</u> min			--	

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = <u>50</u> mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			--
	$I_{Peak}$ (A) max. value.....:	4,88kA	4,97kA	4,66kA	--
	$I^2t \leq$ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. $I^2t \leq$ _____ kA <sup>2</sup> s	L1 <u>110</u>	L2 <u>128</u>	L3 <u>145</u>	P
		L4(N)	---	---	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n =$ <u>457</u> V. The circuit – breaker is in the open position	$E_{1-1}$ [mA]	$E_{1-2}$ [mA]	$E_{1-3}$ [mA]	--
	The leakage current shall not exceed 2 mA	L1 <0,01	<0,01	<0,01	P
		L2 <0,01	<0,01	<0,01	P
		L3 <0,01	<0,01	<0,01	P
		L4(N) <0,01	<0,01	<0,01	P
	Electric strength test:				P
	Test voltage 1500 V (see 9.7.2)				P
	a)				P
	b)				N/A
	c)				P
	d)				N/A
	e) 2000 V				N/A
	Test current 0.85x non-tripping current (1,13 $I_N$ )	<u>60,8</u> A			--
	- Passed for 1h				P
	- Passed for 2h				N/A

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Current is then steadily increased to 1,1 x tripping current (1,45 I <sub>n</sub> ) within 5s	___101___ A			--
		<b>E<sub>1-1</sub></b> [min]	<b>E<sub>1-2</sub></b> [min]	<b>E<sub>1-3</sub></b> [min]	--
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	<u>5min21s</u>	<u>2min15s</u>	<u>3min21s</u>	P
<b>TESTS „E<sub>1</sub>“ 3 samples D6, 4POLE</b>					<b>P</b>
<b>9.12.11.4.2</b>	<b>Test E<sub>1</sub>: Test at service short-circuit capacity</b>	<b>E<sub>1-1</sub></b>	<b>E<sub>1-2</sub></b>	<b>E<sub>1-3</sub></b>	<b>P</b>
	Service short-circuit capacity (I <sub>cs</sub> ) .....	<u>6kA</u>			--
	Test circuit: figure .....	<u>3</u>			--
	Test voltage 1,05 Un	<u>438V</u>			--
	Prospective current .....	<u>6,0kA</u>			--
	Prospective current obtained .....	<u>6,24 kA</u>			--
	Power factor .....	<u>0,65...0,70</u>			--
	Power factor obtained .....	<u>0,67</u>			--
	Sequence .....	<u>O – O – CO</u>			--
	T (min) .....	<u>3</u> min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = <u>50</u> mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--
	I <sub>Peak</sub> (A) max. value .....	<u>2,89kA</u>	<u>3,07kA</u>	<u>3,92kA</u>	--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	<u>18,9</u>	<u>34,5</u>	<u>43,8</u>	P
		L1			
		L2			
		L3			
		L4(N)			
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = \underline{\quad 457 \quad}$ V. The circuit – breaker is in the open position	<b>E<sub>1-1</sub></b> [mA]	<b>E<sub>1-2</sub></b> [mA]	<b>E<sub>1-3</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	P
		L2	<0,01	<0,01	<0,01	P
		L3	<0,01	<0,01	<0,01	P
		L4(N)	<0,01	<0,01	<0,01	P
	Electric strength test:				P	
	Test voltage 1500 V (see 9.7.2)				P	
	a)				P	
	b)				N/A	
	c)				P	
	d)				N/A	
	e) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 $I_N$ )	<u>5,80</u> A			--	
	- Passed for 1h				P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 $I_N$ ) within 5s	<u>9,60</u> A			--	
		<b>E<sub>1-1</sub></b> [min]	<b>E<sub>1-2</sub></b> [min]	<b>E<sub>1-3</sub></b> [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	<u>5min11s</u>	<u>3min20s</u>	<u>2min11s</u>	P	

TESTS „E <sub>2</sub> “ 3 + 4 samples					
<b>9.12.11.4.3</b>	<b>Test: E2 (Test at rated short-circuit capacity)</b>	<b>E<sub>2-1</sub></b>	<b>E<sub>2-2</sub></b>	<b>E<sub>2-3</sub></b>	<b>N/A</b>
	Rated short-circuit capacity ( $I_{cn}$ ).....:				--
	Test circuit: figure .....				--
	Test voltage 1,05 $U_n$				--
	Prospective current .....				--
	Prospective current obtained.....:				--
	Power factor .....				--
	Power factor obtained .....				--



IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Sequence .....	_____			--
	T (min) .....	_____min			--
9.12.9.2	Test in free air copper wire F': <input checked="" type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = _____ mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--
	I <sub>Peak</sub> (A) max. value .....				--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1 —	—	—	N/A
		L2 —	—	—	
		L3 —	—	—	
		L4(N) —	—	—	
	- No permanent arcing				N/A
	- No flash-over between poles or between poles and frame				N/A
	- No blowing of the fuses F and F'				N/A
	- Polyethylene foil shows no holes				N/A
	After the test:				--
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				N/A
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U <sub>n</sub> . = _____ V. The circuit – breaker is in the open position	E <sub>2-1</sub> [mA]	E <sub>2-2</sub> [mA]	E <sub>2-3</sub> [mA]	--
	The leakage current shall not exceed 2 mA	L1 <0,01	<0,01	<0,01	N/A
		L2			N/A
		L3			N/A
		L4(N)			N/A
	Electric strength test:				N/A
	Test voltage 900 V (see 9.7.3)				N/A
	a)				N/A
	b)				N/A
	c)				N/A
	d)				N/A
	e)				N/A
	Test current 2,8 I <sub>N</sub>	_____A			N/A

IEC 60898-1							
Clause	Requirement + Test	Result - Remark				Verdict	
	Tripping within > 0,1 s up to	[s]	[s]	[s]		--	
	- 60 s					N/A	
	- 120 s					N/A	
<b>9.12.11.4.3</b>	<b>Test „E<sub>2</sub>“(Test at rated short-circuit capacity) three phase tests for single circuit-breakers</b>	<b>E<sub>2-4</sub></b>	<b>E<sub>2-5</sub></b>	<b>E<sub>2-6</sub></b>	<b>E<sub>2-7</sub></b>	<b>N/A</b>	
	Rated short-circuit capacity (I <sub>cn</sub> ).....:					--	
	Test circuit: figure .....					--	
	Test voltage 1,05 Un					--	
	Prospective current .....					--	
	Prospective current obtained.....:					--	
	Power factor .....					--	
	Power factor obtained .....					--	
	Sequence .....					--	
	T (min) .....	_____ min				--	
9.12.9.2	Test in free air copper wire F': <input checked="" type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	"a" = _____ mm				--	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm				--	
	I <sub>Peak</sub> (A) max. value .....					--	
	- No permanent arcing					N/A	
	- No flash-over between poles or between poles and frame					N/A	
	- No blowing of the fuses F and F'					N/A	
	- Polyethylene foil shows no holes					N/A	
	After the test:					--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					N/A	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U <sub>n</sub> . = _____ V. The circuit – breaker is in the open position	<b>E<sub>2-4</sub></b> [mA]	<b>E<sub>2-5</sub></b> [mA]	<b>E<sub>2-6</sub></b> [mA]	<b>E<sub>2-7</sub></b> [mA]	--	
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01	<0,01	N/A
		L2					N/A
		L3					N/A
		L4(N)					N/A

IEC 60898-1						
Clause	Requirement + Test	Result - Remark				Verdict
	Electric strength test:					N/A
	Test voltage 900 V (see 9.7.3)					N/A
	a)					N/A
	b)					N/A
	c)					N/A
	d)					N/A
	e)					N/A
	Test current 2,8 I <sub>N</sub>	_____ A				N/A
	Tripping within > 0,1 s up to	[s]	[s]	[s]	[s]	--
	- 60 s					N/A
	- 120 s		7			N/A

TESTS „E <sub>3</sub> “ 3 samples						N/A
<b>9.12.11.4.4</b>	<b>Test: E<sub>3</sub> (Test at making and breaking capacity on an individual pole (I<sub>cn1</sub>))</b>	<b>E<sub>3-1</sub></b>	<b>E<sub>3-2</sub></b>	<b>E<sub>3-3</sub></b>	N/A	
	I <sub>cn1</sub> .....	_____ kA				--
	Test circuit: figure .....	_____				--
	Test voltage 1,05 U <sub>n</sub>	_____ V				--
	Prospective current .....	_____ kA				--
	Prospective current obtained .....	_____ kA				--
	Power factor .....					--
	Power factor obtained .....					--
	Sequence .....	_____ O-CO _____				--
	T (min) .....	_____ min				--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = _____ mm				--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm				--
	I <sub>Peak</sub> (A) max. value .....	_____ 5,19 kA				--
	I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	[kA <sup>2</sup> s]	--	
	Max. I <sup>2</sup> t ≤ _____ kA <sup>2</sup> s	L1	L2	L3	L4	
		_____	_____	_____	_____	
		_____	_____	_____	_____	
		_____	_____	_____	_____	
	- No permanent arcing					

IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- No flash-over between poles or between poles and frame				
	- No blowing of the fuses F and F'				
	- Polyethylene foil shows no holes				
	After the test:				
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = \underline{\quad 253 \quad}$ V. The circuit – breaker is in the open position	<b>E<sub>3-1</sub></b> [mA]	<b>E<sub>3-2</sub></b> [mA]	<b>E<sub>3-3</sub></b> [mA]	--
	The leakage current shall not exceed 2 mA	L1	<0,01	<0,01	<0,01
		L2			N/A
		L3			N/A
		L4			N/A
	Electric strength test:				
	Test voltage 900 V (see 9.7.3)				
	a)				
	b)				
	c)				
	d)				
	e)				
	Test current 2,8 I <sub>n</sub>	_____ A			
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--
	- 60 s				
	- 120 s				N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex E			N/A
	Special requirements for auxiliary circuits for safety extra-low voltage		N/A
<b>8.1.3</b>	<b>Clearances and creepage distances</b>		N/A
	Additional note to table 4 NOTE 4 live parts in auxiliary circuits intended to be connected to safety extra low voltages shall be separated from circuits with higher voltages in accordance with the requirements of 411.1.3.3 of IEC 60364-4-41		--
	Compliance is checked by inspection		N/A
<b>9.7.4</b>	<b>Dielectric strength of the auxiliary circuits</b>		N/A
	Note: A test for circuits intended for connection to safety extra-low voltage is under consideration		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex J			N/A
	Particular requirements for circuit-breakers with screw less type terminals for external copper conductors (In not exceeding 20 A, cross-sectional area up to 4 mm <sup>2</sup> )		N/A
<b>J.6</b>	<b>Marking</b>		<b>N/A</b>
	Universal terminals		--
	- no marking		N/A
	Non-universal		--
	- declared for rigid-solid conductors .....	marked with: "sol"	N/A
	- declared for rigid(solid and stranded) .....	marked with: "r"	N/A
	- declared for flexible conductors .....	Marked with: "f"	N/A
	The markings should appear on the circuit-breaker or, if available space is not sufficient, on smallest package unit or in technical information .....		N/A
	Indication of length of insulation to be removed on the circuit-breaker.....	_____mm	N/A
<b>J.7</b>	<b>Standard conditions for operation in service</b>		N/A
	Clause 7 applies		N/A
<b>J.8</b>	<b>Constructional requirements</b>		N/A
	Clause 8 applies with the follow modifications:		N/A
	In clause 8.1.5 only -5.1, -5.2. -5.3, - 5.6 and - 5.7 apply		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
<b>J.8.1</b>	<b>Connection or disconnection of conductors</b>		N/A
	The connection or disconnection shall be made by:		N/A
	A general purpose tool or by a convenient device integral with the terminal or		N/A
	for rigid conductors by simple insertion		N/A
	For disconnection an operation other than a pull shall be necessary (push-wire terminals)		N/A
	Universal terminals shall accept rigid (solid or stranded and flexible unprepared conductors		N/A
	Non-universal terminals shall accept conductors declared by the manufacturer		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
<b>J.8.2</b>	<b>Dimensions of connectable conductors</b>		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The dimensions of connectable conductors are given in table J.1		N/A
	The ability to connect these conductors shall be checked by inspection and by the tests of J.9.1 and J.9.2		N/A
<b>J.8.3</b>	<b>Connectable cross-sectional areas</b>		N/A
	The nominal cross-sections to be clamped are given in table J.2		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
<b>J.8.4</b>	<b>Insertion and connection of conductors</b>		N/A
	The insertion and disconnection of the conductors shall be made in accordance with the manufacturer's instructions		N/A
<b>J.8.5</b>	<b>Design and construction of terminals</b>		N/A
	Terminals shall be designed and constructed that:		N/A
	- each conductor is clamped individually		N/A
	- connection or disconnection connectors connected or disconnected separate or same		N/A
	- inadequate insertion of the conductor is avoided		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
<b>J.8.6</b>	<b>The terminals shall be resistant to ageing</b>		N/A
	Compliance is checked by the tests of J.9.3		N/A
<b>J.9</b>	<b>Tests</b>		--
	Clause 9 applies, by replacing 9.4 and 9.5 by the follow		N/A
<b>J.9.1</b>	<b>Test of reliability of screw less terminals</b>		N/A
<b>J.9.1.1</b>	<b>Reliability of screw less system</b>		N/A
	5 times connection and disconnection		N/A
	3 rigid conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> _____ mm <sup>2</sup>	N/A
	3 flexible conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> _____ mm <sup>2</sup>	N/A
	After tests, the terminal shall not be damage in such a way as to impair its further use		N/A
<b>J.9.1.2</b>	<b>Test of reliability of connection</b>		N/A
	3 terminals of poles of new sample are fitted with new copper conductors according table J.2		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	rigid conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> _____ mm <sup>2</sup>	N/A
	flexible conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> _____ mm <sup>2</sup>	N/A
	Each conductor is either pushed as far as possible into the terminal or shall be inserted so that adequate connection is obvious		N/A
	After tests, no wire of the conductor shall have escaped outside the terminals		N/A
<b>J.9.2</b>	<b>Tests of reliability of terminals for external conductors: Mechanical strength</b>		N/A
	Three terminals of new samples are fitted with new conductors of the type and of the minimum and maximum cross sectional area according table J.2.		N/A
	Each conductor is subjected to a pull force of value shown in table J.3. for 1 min		N/A
	Terminal screw torque : $\frac{2}{3}$ of table 11	_____ Nm	N/A
	rigid conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> / _____ N _____ mm <sup>2</sup> / _____ N	N/A
	flexible conductors min. cross-section max. cross-section	_____ mm <sup>2</sup> / _____ N _____ mm <sup>2</sup> / _____ N	N/A
	During the test the conductor shall not slip out of the terminal		N/A
<b>J.9.3</b>	<b>Cycling test</b>		N/A
	The test is carried out with new copper conductors having a cross sectional area according table 10	_____ mm <sup>2</sup>	N/A
	The test is carried out on new samples( a sample is one pole, the number of which is defined below, according the type of terminal		N/A
	- universal terminals for rigid (solid and stranded) and flexible conductors	3 + 3 samples	N/A
	- non-universal terminals for solid conductors only	3 samples	N/A
	-- non- universal terminals for rigid (solid and stranded) conductors	3 + 3 samples	N/A
	- non-universal terminals for flexible conductors only	3 samples	N/A
	The conductors are connected in series as in normal use to each of the three samples as defined on fig. J.1.		N/A



IEC 60898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	The sample is provided with a hole or equivalent in order to measure the voltage drop on the terminal				N/A
	The test arrangement is placed in a heating cabinet which is initially on 20°C				N/A
	Except the cooling period the test current (rated current) is applied to the circuit	I test _____ A			N/A
	The samples shall be subjected to 192 temperature cycles, each cycle having a duration of +/- 1 hour				N/A
	Description of the temperature cycle: In 20 min raised to 40°C, maintained for 10 min, then cool down in 20 min to 30 °C, maintained for 10 min. For measurement of the voltage drop it is allowed to cool down to 20 °C				N/A
	The maximum voltage drop, measured on each terminal, at the end of the 192 <sup>nd</sup> cycle, with Inom. shall not exceed the smaller of the two following values <ul style="list-style-type: none"> <li>- either 22,5 mV</li> <li>- or 1,5 times the value measured after the 24 cycle</li> </ul>	Uv max. _____ mV			N/A
	Sample after 24 cycles: rigid conductors (mV) flexible conductors (mV)	J <sub>1</sub> _____ _____	J <sub>2</sub> _____ _____	J <sub>3</sub> _____ _____	N/A
	Sample after 192 cycles: rigid conductors (mV) flexible conductors (mV)	J <sub>1</sub> _____ _____	J <sub>2</sub> _____ _____	J <sub>3</sub> _____ _____	N/A
	After this test the samples shall show no changes evidently impairing further use, such as cracks, deformations or like				N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex K			N/A
	Particular requirements for circuit-breakers with flat quick-connect terminations		--
<b>K.6</b>	<b>Marking</b>		N/A
	The whole of clause 6 applies		N/A
	Addition after the lettered item k		--
	The following information regarding the female connector according to IEC 61210 and the type of conductor to be used shall be given in the manufacturer's instructions		N/A
	a) manufacturers name or trade mark		--
	b) type reference		N/A
	c) information on cross-sections of conductors and colour code of insulating female connectors (see table K.1)		N/A
	d) the use of only silver or tin-plated copper alloys		N/A
<b>K.7</b>	<b>Standard conditions for operation in service</b>		N/A
	Clause 7 applies		N/A
<b>K.8</b>	<b>Constructional requirements</b>		N/A
	Clause 8 applies with the follow modifications:		N/A
	replacement of 8.1.3 by:		N/A
<b>K.8.1</b>	<b>Clearances and creepage distances (see annex B)</b>		N/A
	Subclause 8.1.3 applies, the female connectors being fitted to the male tabs of the circuit-breaker		N/A
	Replacement of 8.1.5 by:		N/A
<b>K.8.2</b>	<b>Terminals for external conductors</b>		N/A
K.8.2.1	Male tabs and female connectors shall be of a metal having mechanical strength, electrical conductivity and resistance to corrosion adequate for their intended use		N/A
K.8.2.2	The nominal width of male tab is 6,3 mm and the thickness 0,8 mm, applicable to rated currents up to and including 16 A NOTE 1: The use for rated currents up to and including 20 A is accepted in BE, FR, IT, PT, ES and US		N/A
	The dimensions of the male tab shall comply with those specified in table K.3 and in figures K.2, K3, K4, K5, where the dimensions A, B, C, D, E, F, J, M, N and Q are mandatory		N/A

<b>IEC 60898-1</b>			
Clause	Requirement + Test	Result - Remark	Verdict
	The dimensions of the female connector which may be fitted-on are given in figure K.6 and in table K.4		N/A
	Compliance is checked by inspection and by measurement	See table on page _____	N/A
<b>K.8.2.3</b>	<b>Male tabs shall be securely retained</b>		N/A
	Compliance is checked by the mechanical overload test of K.9.1		N/A
<b>K.9</b>	<b>Tests</b>		N/A
	Clause 9 applies, with follow modifications:		N/A
	Replacement of 9.5 by:		N/A
<b>K.9.1</b>	<b>Mechanical overload-force</b>		N/A
	10 terminals of circuit-breakers, mounted as normal use are subjected to a axial push force and successively the axial pull force specified in table K2 applied to male tab once	push force 96 N pull force 88 N	N/A
	No damage which could impair further use shall occur to the tab or to the circuit-breaker in which the tab is integrated		N/A
	Addition to 9.8.3:		N/A
	Fine –wire thermocouples shall be placed in such a way as not to influence the contact or the connection area. An example of placement is shown in fig K.1		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

		Dimensions of tabs according Table K.3		Measured in mm	Verdict
		Minimum	Maximum		N/A
A	Dimple	0,7	1,0	_____	N/A
	Hole	0,5	1,0	_____	N/A
B	Dimple	7,8 min		_____	N/A
	Hole	7,8 min		_____	N/A
C	Dimple	0,77	0,84	_____	N/A
	Hole	0,77	0,84	_____	N/A
D	Dimple	6,20	6,40	_____	N/A
	Hole	6,20	6,40	_____	N/A
E	Dimple	3,6	4,1	_____	N/A
	Hole	4,3	4,7	_____	N/A
F	Dimple	1,6	2,0	_____	N/A
	Hole	1,6	2,0	_____	N/A
J	Dimple	8°	12°	_____	N/A
	Hole	8°	12°	_____	N/A
M	Dimple	2,2	2,5	_____	N/A
	Hole	---	---	---	---
N	Dimple	1,8	2,0	_____	N/A
	Hole	---	---	---	---
P	Dimple	0,7	1,8	_____	N/A
	Hole	0,7	1,8	_____	N/A
Q	Dimple	8,9 min	---	_____	N/A
	Hole	8,9 min	---	_____	N/A
B3			7,8 max	_____	N/A
L2			3,5 max	_____	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex L			N/A
	Specific requirements for circuit-breakers with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors		N/A
<b>L.6</b>	<b>Marking</b>		<b>N/A</b>
	In addition to clause 6 the following apply:		N/A
	Terminal marking according table L.1, on the circuit breaker, near the terminals		--
	Conductor types accepted:		N/A
	Copper only	<input type="checkbox"/> None	N/A
	Aluminium only	<input type="checkbox"/> "Al"	N/A
	Aluminium and copper	<input type="checkbox"/> "Al/Cu"	N/A
	Other information concerning the number of conductors, screw torque (if different from table 11) and cross-section shall be indicated on the circuit-breaker	_____ Nm _____ mm <sup>2</sup>	N/A
<b>L.7</b>	<b>Standard conditions for operation in service</b>		N/A
	Clause 7 applies		N/A
<b>L.8</b>	<b>Constructional requirements</b>		N/A
	Clause 8 applies with the following exceptions:		N/A
8.1.5.2	is completed by:		N/A
	For connection of aluminium conductors, circuit-breakers shall be provided with screw-type terminals allowing the connection of conductors having nominal cross-sections as shown in table L.2		N/A
	Terminals for the connection of aluminium conductors and terminals of aluminium for the connection of copper or aluminium conductors shall have mechanical strength adequate to withstand the tests of 9.4, with the test conductors tightened with the torque indicated in table 11, or with the torque specified by the manufacturer, which shall never be lower than that specified in table 11.		N/A
	Compliance is checked by inspection, by measurement and by fitting in turn one conductor of the smallest and one of the largest cross-section areas as specified		N/A
8.1.5.4	Terminals shall allow the conductors to be connected without special preparation		N/A
	Compliance is checked by inspection and by the tests of L.9		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict
<b>L.9</b>	<b>Tests</b>		N/A
	Clause 9 applies with the following modifications/additions:		N/A
	For the tests which are influenced by the material of the terminal and the type of conductor that can be connected, the test conditions of table L.3 are applied		N/A
	Additionally the test of L.9.2 is carried out on terminals separated from the circuit-breaker		N/A
<b>L.9.2</b>	<b>Current cycling test</b>		N/A
	This test is carried out on separate terminals		N/A
	The general arrangement of the samples shall be as shown in figure L.1		N/A
	90 % of torque stated by the manufacturer or selected in table 11 used for the specimens	torque:_____Nm	N/A
	The test is carried out with conductors according to table L.5. The length of the test conductor from the point of entry to the screw-type terminal specimens to the equalizer shall be as in table L.6	cross-section:_____mm <sup>2</sup> minimum conductor length:_____mm	N/A
	Cross section of equalizer not greater than that given in table L.7	max. crosssection_____mm <sup>2</sup>	N/A
L.9.2.5	Test method and acceptance criteria		N/A
	Test loop subjected to 500 cycles of 1h current-on and 1h current-off, starting at an a.c. current value of 1,12 times the test current value determined in table L.8	test current:_____A	N/A
	Near the end of each current-on period of the first 24 cycles, the current shall subsequently be adjusted to raise the temperature of the reference conductor to 75°C		N/A
	At the end of the 25 <sup>th</sup> cycle the test current shall be adjusted the last time and the stable temperature shall be recorded as the first measurement. No further adjustment of test current for the remainder of the test		N/A
	Temperatures recorded for at least one cycle of each working day, and after approximately 25, 50, 75, 100, 125, 175, 225, 350, 425 and 500 cycles		N/A
	For each screw-type terminal		N/A
	- the temperature rise shall not exceed 110 K		N/A
	- the stability factor Sf shall not exceed ± 10 °C		N/A

IEC 60898-1				
Clause	Requirement + Test	Result - Remark		Verdict
	ambient air temperature: _____ °C	max. temperature rise [K]	max. stability factor Sf [°C]	N/A
	Terminal 1			N/A
	Terminal 2			N/A
	Terminal 3			N/A
	Terminal 4			N/A
	Terminal 5			N/A
	Terminal 6			N/A
	Terminal 7			N/A
	Terminal 8			N/A

TABLE: Heating Test			P
Test voltage (V) .....		:	—
Ambient (°C) .....		:	—
Thermocouple Locations	max. temperature measured, (K)	max. temperature limit, (K)	
Supplementary information: Refer to test sequence B of this test report about temperature rise			

TABLE: Dielectric Strength			P
Test voltage applied between:	Test potential applied (V)	Breakdown / flashover (Yes/No)	
Supplementary information: Refer to test sequence B of this test report about Dielectric Strength			

TABLE: insulation resistance measurements			N/A
Insulation resistance R between:	R (MΩ)	Required R (MΩ)	
Between mains poles (primary fuse disconnected)		N/A	
Between parts separated by basic or supplementary insulation		N/A	
Between parts separated by double or reinforced insulation		N/A	
Supplementary information:			



TABLE: Impact Resistance				N/A
Impacts per surface	Surface tested	Impact energy (Nm)	Comments	

Supplementary information:

TABLE: Clearance And Creepage Distance Measurements						P
clearance cl and creepage distance dcr at/of:	Up (V)	U r.m.s. (V)	Required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)

Supplementary information:  
Refer to test sequence A of this test report about Clearance And Creepage Distance

TABLE: Ball Pressure Test of Thermoplastics				P
Allowed impression diameter (mm) .....			2	—
Object/ Part No./ Material	Manufacturer/ trademark	Test temperature (°C)	Impression diameter (mm)	

Supplementary information:  
Refer to test sequence A of this test report about Ball Pressure Test of Thermoplastics

TABLE: Needle- flame test (NFT)					N/A
Object/ Part No./ Material	Manufacturer/ trademark	Duration of application of test flame (ta); (s)	Ignition of specified layer Yes/No	Duration of burning (tb) (s)	Verdict

Supplementary information:

**NFT not relevant (or applicable) for Parts of material classified as V-0 or V-1**

**NFT not relevant (or applicable) for Base material of PCBs classified as V-0 or if relevant VTM-0**

TABLE: Resistance to heat and fire - Glow wire tests								P
Object/ Part No./ Material	Manufacturer / trademark	Glow wire test (GWT); (°C)						Verdict
		550	650		750		960	
			te	ti	te	ti		
Object/ Part No./ Material	Manufacturer / trademark	Glow-wire flammability index (GWFI), °C				GW ignition temp. (GWIT), °C		Verdict
		550	650	750	850	675	775	
		--	--	--				
The test specimen passed the glow wire test (GWT) with no ignition [(te – ti) ≤ 2s] (Yes/No) .....								P
If no, then surrounding parts passed the needle-flame test of annex E (Yes/No)..... :								N/A
The test specimen passed the test by virtue of most of the flaming material being withdrawn with the glow-wire (Yes/No)? .....								N/A
Ignition of the specified layer placed underneath the test specimen (Yes/No)..... :								N/A
Supplementary information:								
550 °C GWT not relevant (or applicable) to parts of material classified at least HB40 or if relevant HBF								
The GWIT pre-selection option, the 850 °C GWFI pre-selection option, and the 850 °C GWT are not relevant (or applicable) for attended appliances.								
Refer to test sequence A of this test report about Resistance to heat and fire								

TABLE: Threaded Part Torque Test				P
Threaded part identification	Diameter of thread (mm)	Column number ( I, II, or III)	Applied torque (Nm)	
Supplementary information:				
Refer to test sequence A of this test report about mechanism.				

IEC60898_1D ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict

<b>ATTACHMENT TO TEST REPORT IEC 60898-1</b> <b>EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES</b> <b>Circuit-breakers for over current protection for household and similar installations</b> <b>Part 1 - Circuit-breakers for a.c. operation</b>		
<b>Differences according to .....</b>	EN 60898-1:2019	
<b>Attachment Form No. ....</b>	EU_GD_IEC60898_1D	
<b>Attachment Originator .....</b>	DEKRA Certification B.V.	
<b>Master Attachment.....</b>	2019-06-18	
<b>Copyright © 2019 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.</b>		
	<b>CENELEC COMMON MODIFICATIONS (EN)</b>	-
<b>Test item particulars:</b>		-
Type of circuit-breaker .....	YCB9-63	-
Energy limiting class .....	<input checked="" type="checkbox"/> Class 1 <input type="checkbox"/> Class 3	-
Value of rated operational voltage (Ue) and number of poles .....	<input checked="" type="checkbox"/> 230 V <input checked="" type="checkbox"/> 1 P <input checked="" type="checkbox"/> 230/400 V <input type="checkbox"/> 1 P + N <input checked="" type="checkbox"/> 400 V <input checked="" type="checkbox"/> 2 P <input checked="" type="checkbox"/> 3 P <input type="checkbox"/> 3 P + N <input checked="" type="checkbox"/> 4 P	P
Value of rated short-circuit capacities above 10 000 A up to and including 25 000 A.....	<input type="checkbox"/> 15000 A <input type="checkbox"/> 20000 A <input type="checkbox"/> 25000 A	N/A
Rated impulse withstand voltage (Uimp)	4 kV	-

IEC60898_1D ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict
	<b>Sequence A<sub>1</sub></b>		
<b>6</b>	<b>MARKING AND OTHER INFORMATION</b>		--
<b>6.1</b>	<b>Standard marking:</b>		--
	f) Rated short circuit capacity in A within a rectangle, without symbol "A" .....	<b>6000 in rectangle</b>	P
	h) calibration temperature, if different from 30°C		P
	m) .....Energy limiting class in a square in accordance with annex ZA.		N/A
	Icn and the energy limiting class, when applied, marked both on the device and combined		P
	Irrespective of type (B, C or D), the manufacturer published in his literature the I <sup>2</sup> t characteristic		P
	For rail mounting circuit-breakers, appropriate rail(s) are indicated in manufacturer's documentation.		P
<b>6.2</b>	<b>Additional marking</b>		--
	Additional marking to other standards (EN or IEC or other) is allowed under the follow conditions:		--
	- the circuit-breaker complies with all the requirements of the additional standard;		--
	- the relevant standard to which the additional marking refers is indicated adjacent to this marking and is clearly differentiated or separated from the standard marking according to cl. 6.1		--
<b>6.3</b>	<b>Guidance table for marking</b>		--
	Each CB shall be marked in a durable manner with all or, for small apparatus, according the guidance table for marking.		P
<b>9.6</b>	<b>TEST OF PROTECTION AGAINST ELECTRIC SHOCK</b>		--
	In case of knock-outs the test finger is applied with a force of 10 N		N/A
	<b>Sequence C</b>	<b>C<sub>1</sub></b> <b>C<sub>2</sub></b> <b>C<sub>3</sub></b>	
9.11.1	For single-pole circuit-breakers rated 230/400 V the test is made at 230 V.		P
9.11.3	Dielectric strength reduced to 900 V		P

IEC60898_1D ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict

<b>Sequence C<sub>2</sub> : Short-circuit test on circuit-breakers for use in IT systems</b>			--
9.12.11.2.2	Test voltage 105 % of 400 V	_____ V	P



<b>Sequence D</b>			
<b>9.10</b>	<b>Tests: D<sub>0</sub></b>	<b>D<sub>0-1</sub>    D<sub>0-2</sub>    D<sub>0-3</sub></b>	<b>P</b>
	If the tests are made in a test chamber, it is made in still air; the volume of the chamber has no influence on the test results.		P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type		P
	Test current 3I <sub>n</sub> (A), starting from cold	_____ A	P
	Opening time:	[s]    [s]    [s]	P
	- 0,1 s ≤ t ≤ 45 s (≤ 32A)		P
	- 0,1 s ≤ t ≤ 90 s (> 32A)		P
9.10.2.2	Test current 2,55 I <sub>n</sub> (A) starting from cold for:	_____ A	P
	opening time not less than 1 s or more than	[s]    [s]    [s]	P
	- 60 s (≤ 32 A)		P
	- 120 s (> 32 A)		P
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		P
	Test current 5 I <sub>n</sub> (A), starting from cold	_____ A	P
	Opening time:	[s]    [s]    [s]	P
	- 0,1 s ≤ t ≤ 15 s (≤ 32A)		P
	- 0,1 s ≤ t ≤ 30 s (> 32A)		P
9.10.2.2	Test current 2,55 I <sub>n</sub> (A) starting from cold for:	_____ A	P
	opening time not less than 1 s or more than	[s]    [s]    [s]	P
	- 60 s (≤ 32 A)		P
	- 120 s (> 32 A)		P
9.10.3.4	<input checked="" type="checkbox"/> For circuit-breakers of the D – Type		P
	Test current 10 I <sub>n</sub> (A), starting from cold	_____ A	P
	Opening time:	[s]    [s]    [s]	P
	- 0,1 s ≤ t ≤ 4 s (10 A < I <sub>n</sub> ≤ 32 A)		P
	- 0,1 s ≤ t ≤ 8 s (10 A ≥ I <sub>n</sub> > 32A)		P
	Test current 20 I <sub>n</sub> (A) starting from cold		P
	Tripping less than 0,1 s		P



IEC60898_1D ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.2.2	Test current 2,55 I <sub>n</sub> (A) starting from cold for:	_____ A	P
	opening time not less than 1 s or more than	[s] [s] [s]	P
	- 60 s (≤ 32 A)		P
	- 120 s (> 32 A)		P

Annex ZC		
EN 60898-1		
Special national conditions		
	For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.	
<b>J.1</b>	<b>Austria, Czech Republic, Netherlands, Norway and Switzerland</b>	
	The upper limit of current for use of screwless terminals is 16 A	N/A
<b>J.3.3</b>	<b>Austria, Belgium, Denmark, France, Germany, Italy, Portugal, Spain and Sweden</b>	
	Only universal screwless type terminals are accepted.	N/A
<b>K.1</b>	<b>Belgium, Italy and Spain</b>	
	The use of circuit-breakers with flat quick-connect terminations for rated currents up to and including 20 A is accepted.	N/A
<b>K.8.2.2</b>	<b>Belgium, Italy and Spain</b>	
	The use for rated currents up to and including 20 A is accepted	N/A

**Photographs**



Outer construction of B40,1P:











Outer construction of D63,2P:






Outer construction of D63,4P:





Inter construction 1P B40:



End